

MODELING AND STRESS ANALYSIS OF PIPING SYSTEM

By
ADAM SHA S



College of Engineering
University of Petroleum & Energy Studies
Dehradun
April 2015

MODELING AND STRESS ANALYSIS OF PIPING SYSTEM

A thesis submitted in partial fulfilment of the requirements for the Degree of
Master of Technology
(Pipeline Engineering)

By
ADAM SHA S

Under the guidance of

Mr. RAMESH M
Assistant Professor
Department of Mechanical Engineering
UPES, Dehradun.

Approved

.....

Dean

College of Engineering
University of Petroleum & Energy Studies
Dehradun
April 2015

CERTIFICATE

This is to certify that the work contained in this thesis titled “**MODELING AND ANALYSIS OF PIPING SYSTEM**” has been carried out by **ADAM SHA S** under my supervision and has not been submitted elsewhere for a degree.

Mr.Ramesh M

Assistant Professor,

Department of Mechanical Engineering,

University of Petroleum and Energy Studies,

Dehradun,

Uttarakhand.

ACKNOWLEDGEMENT

We have taken efforts in this project. However, it would not have been possible without the kind support and help of many individuals and organizations. We would like to extend our sincere thanks to all of them

First and Foremost, I would like to thank the All Mighty, God who enabled me to embark upon this carrying on with this work.

Secondly, I would like to thank my project guide, Mr. Ramesh M, Assistant professor, Department of Mechanical Engineering, UPES for his guidance as well as for providing necessary information about the project.

I would like to express my profound thanks and gratitude to Dr. Kamal Bansal, Dean, College of Engineering Studies, University of Petroleum and Energy Studies, Dehradun for providing me the opportunity to pursue my project work.

Also, I am highly indebted to Mr. Haja Mideen at Kagira Drawing solution, Chennai for their guidance and constant supervision as well as for providing necessary information regarding the project and also for his support in completing the project.

I would like to express my special gratitude and thanks to the personnel at Kagira Drawing Solution, Chennai for allowing me to work on this project at their institute and for giving me their time and attention.

And last but not the least, I am greatly thankful to my parents, without whose encouragement and support, I wouldn't have completed this project successfully. Finally I thank to one and all that helped me directly or indirectly for the completion of this project.

CONTENTS

Nomenclature

Abstract

List of Figures

List of Tables

| | | |
|-----------|------------------------------------|----|
| Chapter 1 | Introduction | 1 |
| 1.1 | Loading and Unloading System | 1 |
| Chapter 2 | Literature Review | 2 |
| Chapter 3 | Elements of a system | 5 |
| 3.1 | Product Booster Pumps | 5 |
| 3.2 | Storage vessel | 6 |
| 3.3 | Loading and Unloading area | |
| 3.4 | Loading rack fire protection | |
| Chapter 4 | Equipment's and Pipe Fittings Used | 10 |
| 4.1 | Pipe | 10 |
| 4.2 | Elbows | 10 |
| 4.3 | Tee | 11 |
| 4.4 | Reducers | 11 |
| 4.5 | Flanges | 12 |
| 4.6 | Gaskets | 12 |
| 4.7 | Spectacle Blinds | 13 |
| 4.8 | Valves | 13 |
| 4.9.1 | Check valves | 13 |
| 4.9.2 | Globe Valves | 15 |
| 4.9.3 | Gate Valves | 16 |
| 4.9.4 | Ball Valves | 16 |
| 4.9.5 | Pressure relief Valves | 17 |

| | | |
|---------------|---|----|
| 4.9.6 | Control Valves | 17 |
| 4.9 | Pumps | 18 |
| Chapter 5 | Code and standards | 20 |
| 5.1 | Codes | |
| 5.1.1 | ASME codes and Applications | 20 |
| 5.2 | Standards | 21 |
| 5.2.1 | API Standards and their applications | 21 |
| 5.3 | Scope of ASME B 31.3 | 21 |
| Chapter 6 | Modeling procedure | 22 |
| 6.1 | Piping and Instrumentation diagram | 22 |
| 6.2 | Line size calculations | 23 |
| 6.3 | SP3D | 24 |
| 6.3.1 | Piping Layout Requirement | 25 |
| 6.4 | Isometric Drawings | 26 |
| 6.5 | Pipe Thickness Calculation and selection of schedule for the pipe | 28 |
| Chapter 7 | Stress analysis | 31 |
| 7.1 | Pipe Stress analysis using Caesar II | 31 |
| 7.2 | Building of the model in Caesar II | 32 |
| 7.3 | Load Cases to be considered in pipe stress analysis | 33 |
| 7.3.1 | Sustained Load Case | |
| 7.3.1.1 | Code Compliance report | 34 |
| 7.3.1.2 | Restrain report | 37 |
| 7.3.1.3 | Stress report | 38 |
| 7.3.2 | Operation Load case | 50 |
| 7.3.2.1 | Displacement loads | 51 |

| | |
|----------------------------|----|
| 7.2.2.2 Restrain report | 54 |
| 7.3.3 Expansion Load case | 55 |
| 7.3.3.1 Expansion Loop | 60 |
| 7.4.4 Occasional load Case | 71 |
| 7.4.4.1 Seismic loads | 71 |
| 7.4.4.2 Wind loads | 72 |
| 7.4.4.3 Wave loads | 73 |
| Chapter 8 Conclusion | 74 |
| References | 75 |

Nomenclature

P = initial pressure, psi

D_o = outside diameter, inch

S = allowable stress, psi

A = allowance, additional thickness provided for material removed by threading, corrosion etc.

Y = coefficient that takes material properties and design temperature into account

t_m = Nominal thickness, inch

L = Span length, feet

W = weight of the pipeline, Kg/m

W_t = Total weight of the system, Kg/m

T₁ = design temperature, 0°C

T₂ = Operating temperature, 0°C

P₁ = Design pressure, Kg/mm²

P₂ = Operating Pressure Kg/mm²

ABSTRACT

.This project deals with the loading and unloading area of crude oil products after refining.

This location has been divided as Loading & Unloading area. Trucks will enter into the Loading area to load a crude oil product like Kerosene, Petrol, Diesel, Naphtha, Gas etc.

Unloading area will be used to unload Condensate crude oil from various place of plant through trucks. Condensate crude oil will be re circulated for other purpose. In general, Oil & Gas refinery plants are more dangerous due to handling of Flammable products. So, safety is most important part in case of any fire accident. Firefighting system must be used to save the human and commercial resources. Truck Loading & Unloading areas are must be covered by effective Fire Fighting system. Hydrant & Monitors are primary equipment's of Fire Fighting System. Pipe routing must underground in order to avoid the problems to the Truck access in to the area.

The detailed scope of this project involves Development of Piping Layout for a loading and unloading area and its pipe stress analysis using Caesar II. Development of Piping involves Pressure Design of Piping system using ASME Codes, buildup of piping arrangement based on Piping and Instrument diagram in a 3D environment using SP3D. The model that is designed in SP3D is then built up once again in Caesar II where it is then subjected to stress analysis for various load cases like sustained load cases and displacement load cases.

List of Table

| Table No | Description | Page No |
|-----------------|--------------------|----------------|
| 7.3.1.1 | Code Evaluation | 34 |
| 7.3.1.2 | Restrain report | 37 |
| 7.3.1.3 | Stress report | 39 |
| 7.3.2.1 | Displacement | 51 |
| 7.3.2.2 | Restrain report | 54 |
| 7.3.3 | Code Evaluation | 56 |
| 7.3.3.1 | Loop Determination | 61 |

List of figures

| Fig. No | Description | Page No |
|----------------|--|----------------|
| 3.1 | Booster pump | 5 |
| 3.2 | Storage pump | 6 |
| 3.3 | Loading and Unloading area | 6 |
| 3.4 | Isometric view of model | 8 |
| 4.9.1 | Flanged swing check valve | 14 |
| 4.9.1.1 | Wafer type check valve | 15 |
| 4.9.2 | Flanged globe valve | 15 |
| 4.9.3 | Flanged gate valve | 16 |
| 4.9.4 | Ball valve | 17 |
| 4.9.5 | Relief valve | 17 |
| 4.9.6 | Flanged control valve | 18 |
| 7.2 | Modeling of loading and unloading system | 32 |
| 7.3.3.1 | Expansion loop | 61 |

CHAPTER 1

INTRODUCTION

INTRODUCTION

This project involves Development of Piping Layout for a Loading and Unloading area and its analysis using Caesar II. The Piping Layout involves Pressure Design of Piping System using ASME Codes, Buildup of Piping arrangement using P&ID in a 3D environment and stress Analysis of the same using Caesar II.

1.1 LOADING AND UNLOADING SYSTEM

This location has been divided as Loading & Unloading area. Trucks will enter into the Loading area to load a crude oil product like Kerosene, Petrol, Diesel, Naphtha, Gas etc.

Unloading area will be used to unload Condensate crude oil from various place of plant through trucks. Condensate crude oil will be re circulated for other purpose. In general, Oil & Gas refinery plants are more dangerous due to handling of Flammable products. So, safety is most important part in case of any fire accident. Firefighting system must be used to save the human and commercial resources. Truck Loading & Unloading areas are must be covered by effective Fire Fighting system. Hydrant & Monitors are primary equipment's of Fire Fighting System. Pipe routing must underground in order to avoid the problems to the Truck access in to the area.

CHAPTER 2

LITERATURE REVIEW

Prachi N. Tambe, Dr. Kishor K Dhande, Prof. N. I. Jamadar published a paper on **Flexibility and Stress Analysis of Piping System using CAESAR II** in which Process Plant can be operated safely and efficiently with the help of good design of equipment's and piping systems connecting to the various equipment's like tanks, heat exchangers, pumps etc. Design of piping system includes the pipe and fitting sizing, thickness calculation, equipment layout, pipe routing, support type, support location finalization and stress analysis. This study explains the stress analysis of piping system as per process piping code ASME B 31.3 using 3D software tool CAESAR II. Major requirements in piping stress analysis are to provide adequate flexibility for absorbing thermal expansion, code compliance for stresses incurred in piping system, safe nozzle loads and displacement. The design is said to be safe if all these are in allowable range as per code. In this study, the criterion of selection of piping system for flexibility analysis is explained analytically. The two piping systems are stress analyzed, compared and the effect of flexibility of piping system on nozzle loads and stresses developed are observed. The software output is discussed and safer piping system is identified.

Navath Ravikiran, V. Srinivas Reddy , G. Kiran Kumar published a paper on **3D Modeling and Stress Analysis of Flare Piping** in which for transportation of fluid, steam or air piping system is widely used. For installing the piping system pipes, flanges, piping supports, valves, piping fittings etc. are used, which are piping elements. They are manufactured as per Codes and standards. Equipment and piping layout design as per process requirement and available space. Above layout made out by the help of General arrangement drawing, plant layout and P& ID. Then after flexibility providing to piping system, for compensate the different loads by the engineer. Stresses in pipe or piping systems are generated due to loads like expansion & contraction due to thermal load, seismic load, wind load, sustained load, reaction load etc. the stress analysis is done by help of software like CAESAR II. In this paper, a Flare pipe line is designed and 3D modeling is prepared in PDMS software. Attention is focused for stress

analysis by Caesar-II software. So that various stress values, forces and deflections are analyzed at each node to make the design at safe operating conditions.

Shweta Bisht and Farheen Jahan published a paper on **An Overview on Pipe Design using caesar II** in which Design of piping system constitutes a major part of the design and engineering effort in the world of fluid conveyance. Stress analysis is a critical component of piping design through which important parameters such as piping safety, safety of related components and connected equipment and piping deflection can be checked and rectified timely. The objective of pipe stress analysis is to prevent premature failure of piping and piping components and ensuring that piping stresses are kept within allowable limits. This paper is designed for studying a wide range of abilities and backgrounds and will cover the fundamental principles and concepts used in pipe stress analysis. In addition to meeting the needs of design, the paper is structured to provide a deep understanding of the engineering principles involved in material selection, application of code criteria and the capabilities and tools incorporated in stress analysis software.

Mr. Suyog U. Bhave published a paper on **Calculation Methodologies for The Design of Piping Systems** in which t- Piping systems are constantly present in industrial facilities, being in some cases associated with the transport of fuels, processing of crude oils and chemical plants. Due to the nature of those fluids, the design of the piping system that transports them is a task of great responsibility, which must follow codes and standards to guarantee the system's structural integrity. Many times the piping systems operate at a temperature higher than the temperature at which they are assembled, leading to the thermal expansion of the system's pipes and since no piping system is free to expand, the thermal expansion will lead to stresses. Besides the stresses caused by thermal expansion, the studied systems will also be subjected to constant loads caused by their weight, as well as occasional loads like wind, earthquake. In this perspective, calculation methodologies were developed in order to do quick analysis of the most common configurations, according to the codes like ASME B31.3, allowing that way improvements on the flexibility of the projected systems.

Bahaa Shehadeh, Shivakumar, Ranganathan, Farid H Abed published paper on Optimization of piping expansion loops using ASME B31.3 in which Piping is the main transportation method for fluids from one location to another within an industrial plant. Design and routing of piping is heavily influenced by the stresses generated due to thermal effects and high pressure of the operating fluid. In particular, pressurized fluids create critical loads on the supports and elbows of the pipe which increases the overall stresses in the piping. Moreover, long pipes operating under high temperature gradients tend to expand significantly. Therefore, designers and engineers usually provide an expansion loop in order to relieve the pipe from the critical stresses. However, expansion loops require extra space, supports, elbows, bends, additional steel structure that could adversely affect the operating cost. It is therefore necessary to optimize the geometry, the number of expansion loops, and the supports. Reducing the number of loops in one single system or reducing the length of the loop itself is always favored as long as stresses are within safe limits. Usually, the commercial software (Pipe Data) is used in the industry to get the dimensions of the expansion loop. However, this software is mostly based on empirical models that rely on past experience rather than engineering fundamentals. Accordingly, this paper conducts an optimization analysis concerning the expansion loop dimensions and the number of supports without compromising on the safety of piping. The design approach is conducted as per the guidelines of ASME B31.3 (Process Piping) code and uses the commercial software (CAESAR II) for stress calculations. A full comparison for the expansion loop dimension is conducted between the empirical approach and the optimization analysis using ASME B31.3 for one of the existing oilfield projects. Results indicate that optimization reduces the dimensions and the number of expansion loops as well as the total number of supports. This results in significant savings in the piping cost without any compromise on the safety.

CHAPTER – 3

ELEMENTS OF A SYSTEM

3.1 PRODUCT BOOSTER PUMP

Crude oil and petroleum products pumping stations and gas compressor stations are located at wellheads and along the pipeline route as needed to maintain pressure and volume. Pumps are driven by electric motors or diesel engines, and turbines may be powered by fuel oil, gas or steam. Many of these stations are automatically controlled and not staffed at most times. Pumps, with and without vapour return lines or pressure equalizing lines, are commonly used in smaller pipelines for transport of LNG, LPG and compressed natural gas (CNG).




Fig 3.1: Booster pumps

The figure 1 shows the pumping of crude oil products from the refinery to the vessel through connecting pipes.

3.2 STORAGE VESSEL

A storage tank is a container, usually for holding liquids, sometimes for compressed gases (gas tank).

Storage tanks are available in many shapes: vertical and horizontal cylindrical; open top and closed top; flat bottom, cone bottom, slope bottom and dish bottom. Large tanks tend to be vertical cylindrical, or to have rounded corners transition from vertical side wall to bottom profile, to easier withstand hydraulic hydrostatically induced pressure of contained liquid. Most container tanks for handling liquids during transportation are designed to handle varying degrees of pressure.




Fig 3.2: storage vessel

The figure 2 represents the storage of petroleum products which are all transferred for distribution from the refinery plant.

3.3 LOADING AND UNLOADING AREA

Trucks will enter into the Loading area to load a crude oil product like Kerosene, Petrol, Diesel, Naphtha, Gas etc. Unloading area will be used to unload Condensate crude oil from various place of plant through trucks. Condensate crude oil will be re circulated for other purpose.




Fig 3.3: Loading and Unloading area

3.4 LOADING RACK FIRE PROTECTION

Fires and explosions at top and bottom tank car and tank truck loading racks may occur from causes such as electrostatic build-up and incendiary spark discharge in a flammable atmosphere, unauthorized hot work, flashback from a vapour recovery unit, smoking or other unsafe practices.

Sources of ignition, such as smoking, running internal combustion engines and hot work activity, should be controlled at the loading rack at all times, and particularly during loading or




Fig 3.4: Fire protection system




Fig 3.5: Loading and Unloading system (Isometric view)

Other operations when a spill or release may occur. Loading racks may be equipped with portable fire extinguishers and manually or automatically operated foam, water or dry chemical

fire extinguishing systems. If vapour recovery systems are in use, flame arrestors should be provided to prevent flashback from the recovery unit to the loading rack.

Drainage should be provided at loading racks to divert product spills away from the loader, tank truck or tank car and the loading rack pad. Drains should be provided with fire traps to prevent migration of flames and vapours through sewer systems. Other loading-rack safety considerations include emergency shut-down controls placed at loading spots and other strategic locations in the terminal and automatic pressure-sensing valves which stop product flow to the rack in case of a leak in the product lines. Some companies have installed automatic brake lock systems on their tank truck fill connections, which lock the brakes and will not allow the truck to be moved from the rack until the fill lines have been disconnected.

CHAPTER 4

EQUIPMENT'S AND PIPE FITTINGS USED

4.1 PIPE:

Pipe is a cylindrical conduit used to transfer fluid from one area to another area or from one equipment to another equipment.

If it is placed within a confined area, it is called piping.

If it is spread over several Km then it is called pipeline.

PIPE THICKNESS/PIPE SCHEDULE

Carbon steel/

Aluminum : 5 10 20 30 40 80 100 120 140 160

Stainless steel: 5S 10S 20S 40S 80S 160S

PIPE LENGTHS:

Pipe lengths are of two types' single random length and double random length

- Single random length - 06m - 20ft
- Double random length - 12m - 40f

4.2 ELBOWS:

Elbows are used in pipeline for changing direction. Elbows are classified into three types:

- 90 degree
- 45 degree
- 180 degree

90 degree elbows are again classified into two types:

- 90 degree long radius
- 90 degree short radius.

4.3 TEE

Tee is used to either combine or split fluid flow. It is type of in which T shaped having two outlets. IT is available as

Equal tee

Unequal tee

4.4 REDUCERS:

Reducers are used to reduce the size of line. It is classified into two types,

- Concentric Reducers
- Eccentric reducers

Eccentric reducers are further classified into two types:

- Flat side up
- Flat side down

Eccentric flat side down reducers is used in sleepers & pipe rack to maintain a bottom of pipe. It is also used in control station assembly if spool available is less than supporting of a line.

Eccentric flat side up reducers is used in suction line to avoid cavitation, in concentric reducers air gets constrained to the liquid causing cavitation of the impeller.

4.5 FLANGES:

Flanges are classified on basis of follows:

- Weld neck
- Slip on
- Socket weld
- Threaded
- Orifice flange
- Slip End/ Lap joint

Weld Neck Flanges:

Weld neck flanges have a taper hub, which makes a more robust for high pressure and high temperature application. These types of flanges are most recommended for above 2 inch

4.6 GASKETS:

Gaskets are used between the flanges to have a leak proof joint and form a good mechanical interlock. The gaskets are selected based on:

- Pressure and temperature of fluid,
- Corrosion nature of fluid

Gaskets are of three types:

- Metallic
- Non-metallic
- Semi-metallic

4.7 SPECTACLE BLIND:

Spectacle blind also known as figure 8 blind, is generally a piece of metal that is cut to fit between two pipe flanges and usually sandwiched between two gaskets. A spectacle blind is often made for two metal discs that are attached to each other by a small section of steel. The shape is similar to pair of glasses or spectacles. Hence the name spectacle blind. One end of blind will have an opening to allow flow through pipe during operation and the other end is solid to block flow during maintenance. They are generally installed as a permanent device to separate process piping system

4.8 valves:

Valves are controls consisting of a mechanical device for controlling, isolating, regulating and ensuring the safety of the flow of a fluid in a line. The types of valves based on their functions are as listed below.

.isolation valves

.regulation valves

.checking valves

.safety valves


.special valves

4.9.1 Check valve:

Check valve used for a unidirectional flow called non return valve. Used in pump discharge line, compressor line etc.

Swing type check valve

It is available from 2" to 36". It is recommended in both horizontal lines and vertical lines. In lines above 16", this valve becomes heavier and hence, not recommended for horizontal lines since there are alternatives available.



| IT. | DESCRIPTION |
|-----|-------------|
| 1 | COVER |
| 2 | BOLT |
| 3 | BODY |
| 4 | HINGE PIN |
| 5 | SEAT RING |
| 6 | HINGE |
| 7 | DISC |

Fig 4.9.1 Flanged swing check valve

Lift type check valve:

It is of two types' ball lift and piston lift. Ball lift is available from $\frac{1}{4}$ " to 2" and can be used on horizontal position as well as vertical position. Piston lift is available from $\frac{1}{4}$ " to 24".

Wafer type check valve:

It is of two types single plate wafer, dual plate wafer. Wafer type check valves are compact in shape API 594 is the standard for the valves.




Fig 4.9.1.1 Wafer type check valve

4.9.2 Globe valve

It is a type of regulation valve used in hydrocarbon power and chemical industries. Globe valve finds its application in the bypass line of control valve. Globe valve has highest pressure drop among all the valves. Also, the water hammer effect is less.




Fig 4.9.2 flanged globe valve

4.9.3 Gate Valve:

It is a type of isolation valve usually recommended for liquid services. PRESSURE DROP is relatively less. Water hammer effect is also less. The gate valve is ideally suited for liquid services. Gate valve is not used for regulation pumps. It is more prone to leakage. In case of lines above 12", Gate valve is usually motor operated becomes difficult.




Fig 4.9.3 Flanged gate valve.

4.9.4 Ball Valve:

It is a type of valve recommended for compressed air, gas and liquid services. Pressure drop is less; water hammer effect is more since it is quarterly operated valve. It can be used for regulation purpose but not for prolonged time. Unlike others valve, it has a packing gland and package material instead of bonnet.




Figure 6-1.—Typical ball valve.

Fig 4.9.4 Flanged Ball valve.

4.9.5 Pressure safety valve (PSV)/ Pressure relief valve (PRV):

The PSV is used for gas services and it is fast in action. Both PSV and PRV are connected to the KNOCKOUT DRUM (K.O. DRUM). The knockout drums separate liquid from the fumes and sends the fumes to the flare area for burning.




Fig 4.9.5 Relief valve

4.9.6 Control Valve:

Control valves are used to control the flow of fluid in the line. The different types of control valves are:

- PCV (Pressure control valve)
- TCV (Temperature control valve)

- LCV (level control valve)
- FCV (Flow control valve)

Control valves are pneumatically operated, hydraulically operated, electrically operated or Solenoid operated valves. These valves are directly controlled by control stations based on the logic diagram prepared by the instrument engineer.




Fig4.9.6 Flanged control valve

4.9 Pumps:

Pumps are mechanical devices that moves fluid or gas by pressure or suction. In Hyderabad industry, pumps are only in liquid services. Pumps are classified into:

- Centrifugal pumps
- Reciprocating pumps
- Rotary pumps
- Diaphragm Pumps

Centrifugal pumps:

In this project, we have used centrifugal pumps for the following reasons.

- Centrifugal pumps are for large quantities of fluid to be pumped at relatively lower head compared to Reciprocating pumps.
- Reciprocating pumps are used to transfer small quantities of liquid to be delivered at large heads.
- Rotary pumps are used for abrasive and viscous fluids.

Centrifugal pumps are classified into horizontal and vertical pumps on the alignment of the motor arrangement.

The horizontal pumps are again classified based on their nozzle arrangement:

- Front suction and top discharge.
- Top suction and top discharge.
- Side suction side discharge.

Vertical pumps are also called as vertical inline pumps and they are recommended when the required NPSH (Nominal pipe size) cannot be met. The NPSH required is provided by the vendor. Always NPSH available shall be greater than the NPSH required better efficiency of the pumps.

CHAPTER 5

CODES AND STANDARDS

5.1 CODES

CODES ARE A SET OF RULES and regulations required for safer design, construction, and erection of a plant. The implementation of codes can lead to hazardous accidents which can claim lives. The failure of implementation of code can also be challenged by law.

5.1.1 ASME codes and their applications

ASME B 31.1 - power piping

ASME B 31.3 -process piping

ASME B 31.4 –liquid hydrocarbon transportation

ASME B 31.8 – gas hydrocarbon transportation

ASME B 31.9 – build service piping

ASME B 31.11 – slurry waste water treatment

ASME B 36.10 – wrought/carbon steel /alloy steel pipe

ASME B 36.19 – stainless steel pipe

ASME B 16.5 – steel flanges below 24”

ASME B 16.20 – metallic gaskets

ASME B 16.21 – nonmetallic gaskets

ASME B 16.9 – butt welded fitting

ASME B 16.11 – socket welded / threaded fitting

ASME B 16.36 – orifice flanges

ASME B 16.48 – spectacle blind

ASME B 16.10 – face to face end to end dimension of valve

5.2 standards

Standards are also called as dimensional standard required maintaining the dimensional uniformity throughout the globe .the failure of implementation of standard can lead to rejection of the manufacturing order.

5.2.1 API standards and their applications

India – **BIS** –bureau of Indian standards

Japan – **JIS** - Japanese industrialization society

America – **ASME** – American standard

America – **API** – American petroleum institute

Britain – **BS** – British standard

Europe – **DIN** –deutsche institute for norming

France – **AFNOR**- association for France & normalization

Saudi – **ARAMCO** –Arabian American company standards

5.3 Scope of ASME b 31.3

This code prescribes requirements for materials and components, design, fabrication, assembly, erection, examination, inspection, and testing of piping.

This code applies to piping for all fluids, including:

- Raw, intermediate, and finished chemicals;
- Petroleum products
- Gas, steam, air, and water;
- Fluidized solids;
- Refrigerants

CHAPTER 6

6.1 PIPING AND INSTRUMENTATION DIAGRAM (P & ID)

It is a schematic representation of pipe and its fittings with instruments and its control which helps in the development of layouts. It is a diagram in the process industry, which shows the piping of the process flow together with the installed equipment and instrumentation.

Different names given for Piping and Instrumentation diagrams in the piping industry are:

PEFS (Process Engineering Flow Schemes)

MFD (Mechanical Flow Diagram)

ELD (Engineering Land Diagram)

EFD (Engineering flow diagram)

The steps involved in the development of P&IDs are the following:

1. Line Sizing

2. Line Numbering

P&IDs play a significant role in the maintenance of the process that it describes. It is critical to demonstrate the physical sequence of equipment and systems, as well as how these systems connect. During the design stage, the diagram also provides the basis for the development of system control schemes, allowing for further safety and operational investigations, such as the hazard and operational study (HAZOP)

6.2 LINE SIZE CALCULATIONS

Line sizing is the first step involved in the development of P&ID. A process engineer evaluates the process to determine the flow rate for a particular process. The process involved in this particular project was evaluated and the flow rate was determined as 2200 GPM and 1600 GPM and the velocity of fluid (Products) is 3.8MPS and 3.25MPS. The calculation is based on the following equation,

$$Q=AV \text{ where}$$

Main Line

The flow in meter cube per second (m^3/sec), $Q=2200 \text{ GPM}$

Therefore, $Q= (2100*3.58) / (1000*60) = 0.1387 \text{ m}^3/\text{sec}$

The area of the pipe in square meter (m^2), $A= (\pi*d^2)/4$

The velocity of the liquid in meter per second (m/sec), $V= 3.8\text{m/sec}$

Substituting the above values in the equation, $Q=AV$, we get $d=0.215\text{m}$

Since a safer design will be choosing an available line size above 0.21m (8.48"), the line size chosen for this project is 0.254m (10")

Branch line

The flow in meter cube per second (m^3/sec), $Q=1600 \text{ GPM}$

Therefore, $Q= (2100*3.58) / (1000*60) = 0.10094 \text{ m}^3/\text{sec}$

The area of the pipe in square meter (m^2), $A= (\pi*d^2)/4$

The velocity of the liquid in meter per second (m/sec), $V= 3.25\text{m/sec}$

Substituting the above values in the equation, $Q=AV$, we get $d=0.19890\text{m}$

Since a safer design will be choosing an available line size above 0.1989 (7.83"), the line size chosen for this project is 0.2032 (8")

6.3 SP3D (Smart Plant 3D)

In this project, the software used for the design of equipment's, structures and piping is SP3D

| | <u>2D software</u> | <u>3D software</u> |
|-----------------------------------|---------------------------|---------------------------------|
| Quality of Output Drawings | Good Checkers required | No need of good checkers |
| Time Consumption | Almost twice the time | Half the time consumed using 2D |
| Clashes | Lots of clashes | Less Clashes |

Table 6.3 comparison between 2d & 3D soft wares

SP3D includes comprehensive functions for all aspects of 3D plant design. Some of them are listed below:


- A fully interactive, intuitive 3D design environment, with a Microsoft office style user interface based on .NET technology
- Hundreds of designers can work concurrently on a project, in a fully controlled manner with visibility of the entire design at all times
- Designers progressively create a highly intelligent 3D design by selecting and positioning parametric components from an extensive catalogue.

- Highly configurable, automatic generation of a wide range of reports and drawings direct from the SP3D database.


6.3.1 Piping Layout Requirements:

The layout of equipment and piping shall be based on the following principles [1] to provide a neat and economical layout, allowing for easy supporting and adequate flexibility to meet equipment allowable nozzle load.

- To locate all the equipment's identified on the equipment list.
- To comply with standards, regulations, codes, piping specification and sound engineering practices
- To maximize safety of personal, equipment of facilities.
- To provide means of escape and access for firefighting.
- To satisfy all the requirements indicated in process documents (P&IDs).
- To minimize shut-down duration.



6.4 ISOMETRIC DRAWINGS




SHOP MATERIAL

| PT NO | DESCRIPTION | NPD (MM) | CMDTY CODE | QTY |
|----------|----------------------|-------------|----------------|-------|
| 1 | Pipe S-STD BE | 250 | PIPEBE142DSCHI | 214.9 |
| 2 | Tee.BE.S-STD | 250X250 | TEE39264D | 1 |
| 3 | 90 Degree Elbow | 250 | 90E39264D | 1 |
| 4 | Weld Neck Flange 150 | 250 | FWN35B150AG | 1 |

**OTHER THAN SHOP
MATERIALS**

| PT NO | DESCRIPTION | NPD (MM) | CMDTY | QTY |
|----------|--|-------------|---------------------------|-----|
| 5 | Gasket,CL 150,G653,0.125"thk,304 spiral wind, graph filled.CS center ring.API-601 | 250 | XDAABZZQSG | 1 |
| 6 | ASTM-A-193 STUDS w/ASTM-A-194-2H hvy hex nuts-120.65 mm length | 22 | YZZZHZZFFF (106)A106 B | 12 |
| 7 | Pipe Material | | | |



6.5 PIPE THICKNESS CALCULATION AND SELECTION OF SCHEDULE FOR THE PIPE

As per ASME B 31.3, thickness of the pipe can be calculated using the following equation

$$t = \frac{P \times D}{2(S \times E + P \times Y)} \quad \dots \dots \dots$$

Where,

P = Internal design pressure in psi

E = Joint efficiency factor based on manufacturing method (ASME B 31.3)

Y = Co-efficient as per ASME B 31.3

D = Outside diameter in inches

T = Pressure design thickness in inches

S = Allowable stress in psi based on ASME 31.3

C = Corrosion allowance

$$t_{\text{nominal}} = t + C$$

$$t_{\text{minimum}} = t_{\text{nominal}} \div 0.875$$

This value of t_{minimum} is the minimum required thickness of the given line including mechanical, corrosion and erosion allowances.

Based on the value of t_{minimum} obtained above, the schedule number is selected for the line using ASME B36.10

FOR 250 MM PIPE DIAMETER

P = 250 BAR=362.59 psi

T = 300⁰C = 572 F

D = 10 = 8.625 (NPS)

C = 3mm ÷ 25.4= 0.118"

E = 1 (seamless tube)

Y = 0.7 as per code ASME B 31.3

S = 17.3 KSI = 17300 psi

$$t = \frac{P \times D}{2(S \times E + P \times Y)}$$

$$t = 362.59 \times 10.75 \div 2[17300 \times 1 + 362.59 \times 0.7] = 0.11102" = 0.00154m$$

$$= 0.11102 + 0.2362 = 0.34722" = 0.008819m$$

$$t_{\text{minimum}} = 0.34722 \div 0.875 = 0.365" = 0.00927m$$

Schedule number = 40 (STD) from ASME B 36.10

FOR 200 MM PIPE DIAMETER

P = 250 BAR=362.59 psi

T = 300⁰C = 572 F

D = 8 = 8.625 (NPS)

C = 3mm ÷ 25.4= 0.118"

E = 1 (seamless tube)

Y = 0.7 as per code ASME B 31.3

S = 17.3 KSI = 17300 psi

$$t = \frac{P \times D}{2(S \times E + P \times Y)}$$

$$t = 362.59 \times 8.625 \div 2[17300 \times 1 + 362.59 \times 0.7] = 0.08907'' = 0.002262\text{m}$$

$$= 0.8907 + 0.2362 = 0.3252'' = 0.008819\text{m}$$

$$t_{\text{minimum}} = 0.3252 \div 0.875 = 0.3716'' = 0.00944\text{m}$$

Schedule number = 40 (STD) from ASME B 36.10

FOR 150 MM PIPE DIAMETER

P = 250 BAR = 362.59 psi

T = 300°C = 572 F

D = 6 = 6.625 (NPS)

C = 3mm ÷ 25.4 = 0.118"

E = 1 (seamless tube)

Y = 0.7 as per code ASME B 31.3

S = 17.3 KSI = 17300 psi

$$t = \frac{P \times D}{2(S \times E + P \times Y)}$$

$$t = 362.59 \times 6.625 \div 2[17300 \times 1 + 362.59 \times 0.7] = 0.00684'' = 0.001737\text{m}$$

$$= 0.8907 + 0.2362 = 0.3046'' = 0.007736\text{m}$$

$$t_{\text{minimum}} = 0.3252 \div 0.875 = 0.3481'' = 0.008842\text{m}$$

Schedule number = 40 (STD) from ASME B 36.10

CHAPTER 7

STRESS ANALYSIS

7.1 PIPE STRESS ANALYSIS USING CEASER II

Once the piping layout has been design in SP3D, the first step is to identify and select the critical lines in the designed system.

Critical lines are selected based on the following criteria [2]:

- Lines connected to the pressure vessels, heat exchanger, air coolers.
- Lines connected to rotating, reciprocating, strain sensitive equipment's.
- Pressure relief/ Blow down system lines.
- Low temperature service (Sub-Zero) lines.
- High temperature Service lines.
- Larger Diameter lines.
- Lines with expansion joint.
- Critical service lines (Lethal contents, high integrity etc.)

In the light of the aforementioned criteria, the following lines of the water injection system has been identified and selected as critical lines, thereby sending them for pipe stress analysis using Caesar II after building up the model once again in the aforementioned software. All the lines in the system are grouped into the following three systems.

The main objectives of the pipe stress analysis are to:

- Satisfy the code requirement in ASME B 31.3.
- Confirm that the piping load on the sensitive equipment do not exceed the allowable values.
- Identify the support locations and special support requirements such as springs, rigid strut etc.

7.2 BUILDING UP OF THE MODEL IN CAESER II

All the critical lines mentioned above, subject to pipe stress analysis are grouped into three systems namely,

- Loading system
- Unloading system
- Fire water system

These systems are then built up once again in Caeser II using the pipe Isometrics drawings obtained from SP3D. They are then checked for the following:

- Wall Thickness
- Temperature
- Pressure




Fig 7.2: Modeling of loading and unloading system

7.3 LOAD CASES TO BE CONSIDERED IN PIPE STRESS ANALYSIS

The stress analysis shall be carried using Caesar II software (version 5.20) and shall comply

With the requirements of the code, standards and specifications defined in section 3.0, and shall take into consideration the following load cases:

- Sustained Load cases
- Operational Load Cases
- Occasional Load cases
- Displacement Load Cases

7.3.1 Sustained Load Cases:

Those loads that act due to forces present during normal operation of the system are called Sustained loads. This shall include only the effects of pressure, pipe deadweight, and insulation

Weight and weight of contents. This case is required to be performed mainly to check if the Code compliance requirements of sustained stress are satisfied by the piping system.

Basically, the live weight and dead weight of the fluid is balanced by means of support at necessary points in the system.

Case 3: (SUS): W+P1

$$S_{sus} \leq S_{allowable}$$

LOAD CASE DEFINITION KEY

CASE 2 (SUS) W+P1

7.3.1.1 CODE COMPLIANCE REPORT

Piping Code: B31.3 = B31.3 -2010, March 31, 2011

***** CODE COMPLIANCE EVALUATION PASSED *****

Highest Stresses: (KPa)

| | | |
|-----------------------|-----------|-----------------------------------|
| Ratio (%): | 78.3 | @Node 2810 LOADCASE: 2 (SUS) W+P1 |
| Code Stress: | 100228.13 | Allowable Stresses: 127966.7 |
| Axial Stress: | 17553.4 | @Node 211 LOADCASE: 2 (SUS) W+P1 |
| Bending Stress: | 119321.7 | @Node 2818 LOADCASE: 2 (SUS) W+P1 |
| Torsion Stress: | 19996.3 | @Node 1780 LOADCASE: 2 (SUS) W+P1 |
| Hoop Stress: | 32222.2 | @Node 58 LOADCASE: 2 (SUS) W+P1 |
| Max Stress Intensity: | 133049.0 | @Node 2818 LOADCASE: 2 (SUS) W+P1 |

Table 7.3.1.1: Code Evaluation

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 2(SUS) | 10 | 34923.5 | 127966.7 | 58 | 47580.5 | 127966.7 | B31.3 |
| 2(SUS) | 58 | 59641.7 | 127966.7 | 59 | 67417.8 | 127966.7 | B31.3 |
| 2(SUS) | 59 | 67417.8 | 127966.7 | 60 | 74295.9 | 127966.7 | B31.3 |
| 2(SUS) | 60 | 54991.7 | 127966.7 | 110 | 64535.8 | 127966.7 | B31.3 |
| 2(SUS) | 110 | 64535.8 | 127966.7 | 120 | 29303.7 | 127966.7 | B31.3 |
| 2(SUS) | 120 | 29303.7 | 127966.7 | 160 | 92514.1 | 127966.7 | B31.3 |
| 2(SUS) | 160 | 92514.1 | 127966.7 | 210 | 71221.0 | 127966.7 | B31.3 |
| 2(SUS) | 210 | 49328.2 | 127966.7 | 211 | 38866.9 | 127966.7 | B31.3 |
| 2(SUS) | 211 | 36973.2 | 127966.7 | 220 | 33020.5 | 127966.7 | B31.3 |
| 2(SUS) | 220 | 33020.5 | 127966.7 | 260 | 25775.2 | 127966.7 | B31.3 |
| 2(SUS) | 260 | 22875.6 | 127966.7 | 310 | 84656.5 | 127966.7 | B31.3 |
| 2(SUS) | 310 | 84656.5 | 127966.7 | 360 | 27868.2 | 127966.7 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 2(SUS) | 360 | 24231.0 | 127966.7 | 410 | 27786.1 | 127966.7 | B31.3 |
| 2(SUS) | 410 | 23608.6 | 127966.7 | 460 | 21918.2 | 127966.7 | B31.3 |
| 2(SUS) | 460 | 21918.2 | 127966.7 | 470 | 30915.6 | 127966.7 | B31.3 |
| 2(SUS) | 470 | 30915.6 | 127966.7 | 480 | 75636.1 | 127966.7 | B31.3 |
| 2(SUS) | 480 | 75636.1 | 127966.7 | 490 | 47074.3 | 127966.7 | B31.3 |
| 2(SUS) | 490 | 47074.3 | 127966.7 | 518 | 32270.4 | 127966.7 | B31.3 |
| 2(SUS) | 518 | 43816.5 | 127966.7 | 519 | 39368.9 | 127966.7 | B31.3 |
| 2(SUS) | 519 | 39368.9 | 127966.7 | 520 | 37100.7 | 127966.7 | B31.3 |
| 2(SUS) | 520 | 28650.9 | 127966.7 | 530 | 18289.8 | 127966.7 | B31.3 |
| 2(SUS) | 530 | 17307.1 | 127966.7 | 540 | 54352.6 | 127966.7 | B31.3 |
| 2(SUS) | 540 | 37949.8 | 127966.7 | 550 | 71257.4 | 127966.7 | B31.3 |
| 2(SUS) | 550 | 48476.0 | 127966.7 | 560 | 52715.1 | 127966.7 | B31.3 |
| 2(SUS) | 560 | 52715.1 | 127966.7 | 610 | 40799.6 | 127966.7 | B31.3 |
| 2(SUS) | 610 | 40854.9 | 127966.7 | 660 | 47616.5 | 127966.7 | B31.3 |
| 2(SUS) | 660 | 47616.5 | 127966.7 | 710 | 46475.5 | 127966.7 | B31.3 |
| 2(SUS) | 710 | 46475.5 | 127966.7 | 760 | 20811.8 | 127966.7 | B31.3 |
| 2(SUS) | 760 | 19242.1 | 127966.7 | 770 | 18415.2 | 127966.7 | B31.3 |
| 2(SUS) | 770 | 18415.2 | 127966.7 | 810 | 20560.5 | 127966.7 | B31.3 |
| 2(SUS) | 810 | 18468.8 | 127966.7 | 860 | 64722.8 | 127966.7 | B31.3 |
| 2(SUS) | 860 | 64722.8 | 127966.7 | 870 | 52108.6 | 127966.7 | B31.3 |
| 2(SUS) | 870 | 52108.6 | 127966.7 | 910 | 63097.1 | 127966.7 | B31.3 |
| 2(SUS) | 910 | 63150.1 | 127966.7 | 960 | 18395.9 | 127966.7 | B31.3 |
| 2(SUS) | 960 | 17320.0 | 127966.7 | 961 | 17311.4 | 127966.7 | B31.3 |
| 2(SUS) | 961 | 15091.2 | 127966.7 | 1010 | 18224.9 | 127966.7 | B31.3 |
| 2(SUS) | 1010 | 17120.6 | 127966.7 | 1060 | 72741.5 | 127966.7 | B31.3 |
| 2(SUS) | 1060 | 72741.5 | 127966.7 | 1110 | 60097.9 | 127966.7 | B31.3 |
| 2(SUS) | 1110 | 60097.9 | 127966.7 | 1160 | 61760.6 | 127966.7 | B31.3 |
| 2(SUS) | 1160 | 61760.6 | 127966.7 | 1210 | 27146.0 | 127966.7 | B31.3 |
| 2(SUS) | 1210 | 27146.0 | 127966.7 | 1260 | 71148.5 | 127966.7 | B31.3 |
| 2(SUS) | 1260 | 71148.5 | 127966.7 | 1310 | 64228.5 | 127966.7 | B31.3 |
| 2(SUS) | 1310 | 64228.5 | 127966.7 | 1360 | 77428.9 | 127966.7 | B31.3 |
| 2(SUS) | 1360 | 78351.1 | 127966.7 | 1410 | 87127.9 | 127966.7 | B31.3 |
| 2(SUS) | 1410 | 87127.9 | 127966.7 | 1460 | 29566.9 | 127966.7 | B31.3 |
| 2(SUS) | 1460 | 29566.9 | 127966.7 | 1510 | 36576.6 | 127966.7 | B31.3 |
| 2(SUS) | 1510 | 36576.6 | 127966.7 | 1518 | 36687.6 | 127966.7 | B31.3 |
| 2(SUS) | 1518 | 41663.4 | 127966.7 | 1519 | 51663.4 | 127966.7 | B31.3 |
| 2(SUS) | 1519 | 51663.4 | 127966.7 | 1520 | 48346.3 | 127966.7 | B31.3 |
| 2(SUS) | 1520 | 39790.1 | 127966.7 | 1530 | 40857.2 | 127966.7 | B31.3 |
| 2(SUS) | 1530 | 39098.6 | 127966.7 | 1532 | 38033.7 | 127966.7 | B31.3 |
| 2(SUS) | 1532 | 38033.7 | 127966.7 | 1540 | 64566.1 | 127966.7 | B31.3 |
| 2(SUS) | 1540 | 51674.0 | 127966.7 | 1550 | 33164.6 | 127966.7 | B31.3 |
| 2(SUS) | 1550 | 27944.6 | 127966.7 | 1560 | 71757.7 | 127966.7 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 2(SUS) | 1560 | 71757.7 | 127966.7 | 1610 | 69003.2 | 127966.7 | B31.3 |
| 2(SUS) | 1610 | 69003.2 | 127966.7 | 1660 | 49054.8 | 127966.7 | B31.3 |
| 2(SUS) | 1660 | 49054.8 | 127966.7 | 1710 | 72881.3 | 127966.7 | B31.3 |
| 2(SUS) | 1710 | 72881.3 | 127966.7 | 1711 | 37066.4 | 127966.7 | B31.3 |
| 2(SUS) | 1711 | 37087.0 | 127966.7 | 1720 | 46344.3 | 127966.7 | B31.3 |
| 2(SUS) | 1720 | 46344.3 | 127966.7 | 1760 | 45828.3 | 127966.7 | B31.3 |
| 2(SUS) | 1760 | 29632.3 | 127966.7 | 1761 | 98422.1 | 127966.7 | B31.3 |
| 2(SUS) | 1761 | 98422.1 | 127966.7 | 1768 | 26434.0 | 127966.7 | B31.3 |
| 2(SUS) | 1768 | 27991.9 | 127966.7 | 1769 | 38595.1 | 127966.7 | B31.3 |
| 2(SUS) | 1769 | 38595.1 | 127966.7 | 1770 | 40040.4 | 127966.7 | B31.3 |
| 2(SUS) | 1770 | 33086.0 | 127966.7 | 1780 | 43831.6 | 127966.7 | B31.3 |
| 2(SUS) | 1780 | 43546.8 | 127966.7 | 1781 | 49964.6 | 127966.7 | B31.3 |
| 2(SUS) | 1781 | 49964.6 | 127966.7 | 1790 | 74259.0 | 127966.7 | B31.3 |
| 2(SUS) | 1790 | 57526.7 | 127966.7 | 1800 | 20211.6 | 127966.7 | B31.3 |
| 2(SUS) | 1800 | 18844.0 | 127966.7 | 1810 | 16722.0 | 127966.7 | B31.3 |
| 2(SUS) | 1810 | 16722.0 | 127966.7 | 1860 | 48044.9 | 127966.7 | B31.3 |
| 2(SUS) | 1860 | 48044.9 | 127966.7 | 1910 | 76932.4 | 127966.7 | B31.3 |
| 2(SUS) | 1910 | 76932.4 | 127966.7 | 1960 | 59851.2 | 127966.7 | B31.3 |
| 2(SUS) | 1960 | 59851.2 | 127966.7 | 2010 | 25993.9 | 127966.7 | B31.3 |
| 2(SUS) | 2010 | 25993.9 | 127966.7 | 2060 | 60112.4 | 127966.7 | B31.3 |
| 2(SUS) | 2060 | 60112.4 | 127966.7 | 2110 | 47107.2 | 127966.7 | B31.3 |
| 2(SUS) | 2110 | 47107.2 | 127966.7 | 2160 | 59214.3 | 127966.7 | B31.3 |
| 2(SUS) | 2160 | 59214.3 | 127966.7 | 2210 | 58183.2 | 127966.7 | B31.3 |
| 2(SUS) | 2210 | 58183.2 | 127966.7 | 2260 | 46622.6 | 127966.7 | B31.3 |
| 2(SUS) | 2260 | 46622.6 | 127966.7 | 2310 | 51726.0 | 127966.7 | B31.3 |
| 2(SUS) | 2310 | 51726.0 | 127966.7 | 2360 | 65050.8 | 127966.7 | B31.3 |
| 2(SUS) | 2360 | 65050.8 | 127966.7 | 2410 | 57245.2 | 127966.7 | B31.3 |
| 2(SUS) | 2410 | 57245.2 | 127966.7 | 2411 | 50563.5 | 127966.7 | B31.3 |
| 2(SUS) | 2411 | 50563.5 | 127966.7 | 2460 | 15509.5 | 127966.7 | B31.3 |
| 2(SUS) | 1360 | 75321.2 | 127966.7 | 2510 | 65565.3 | 127966.7 | B31.3 |
| 2(SUS) | 2510 | 65565.3 | 127966.7 | 2520 | 31483.5 | 127966.7 | B31.3 |
| 2(SUS) | 2520 | 31483.5 | 127966.7 | 2530 | 67242.6 | 127966.7 | B31.3 |
| 2(SUS) | 2530 | 67242.6 | 127966.7 | 2560 | 22099.7 | 127966.7 | B31.3 |
| 2(SUS) | 2560 | 19405.6 | 127966.7 | 2561 | 17872.4 | 127966.7 | B31.3 |
| 2(SUS) | 2561 | 17872.4 | 127966.7 | 2610 | 27293.1 | 127966.7 | B31.3 |
| 2(SUS) | 2610 | 22545.5 | 127966.7 | 2660 | 93343.3 | 127966.7 | B31.3 |
| 2(SUS) | 2660 | 93343.3 | 127966.7 | 2670 | 31132.0 | 127966.7 | B31.3 |
| 2(SUS) | 2670 | 30387.4 | 127966.7 | 2710 | 89644.0 | 127966.7 | B31.3 |
| 2(SUS) | 2710 | 89644.0 | 127966.7 | 2760 | 68284.8 | 127966.7 | B31.3 |
| 2(SUS) | 2760 | 68284.8 | 127966.7 | 2810 | 118129.7 | 127966.7 | B31.3 |
| 2(SUS) | 2810 | 118129.7 | 127966.7 | 2818 | 70075.0 | 127966.7 | B31.3 |
| 2(SUS) | 2818 | 103218.6 | 127966.7 | 2819 | 81937.6 | 127966.7 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 2(SUS) | 2819 | 81937.6 | 127966.7 | 2820 | 73600.6 | 127966.7 | B31.3 |
| 2(SUS) | 2820 | 50475.7 | 127966.7 | 2830 | 67241.4 | 127966.7 | B31.3 |
| 2(SUS) | 2830 | 47422.2 | 127966.7 | 2840 | 81365.9 | 127966.7 | B31.3 |
| 2(SUS) | 2840 | 56777.7 | 127966.7 | 2850 | 91544.1 | 127966.7 | B31.3 |
| 2(SUS) | 2850 | 62724.3 | 127966.7 | 2900 | 56893.2 | 127966.7 | B31.3 |
| 2(SUS) | 2900 | 56893.2 | 127966.7 | 2910 | 114918.9 | 127966.7 | B31.3 |
| 2(SUS) | 2910 | 114918.9 | 127966.7 | 2960 | 54390.0 | 127966.7 | B31.3 |
| 2(SUS) | 2960 | 54390.0 | 127966.7 | 3010 | 103437.1 | 127966.7 | B31.3 |
| 2(SUS) | 3010 | 103485.8 | 127966.7 | 3060 | 61529.4 | 127966.7 | B31.3 |
| 2(SUS) | 3060 | 61529.4 | 127966.7 | 3110 | 105989.9 | 127966.7 | B31.3 |
| 2(SUS) | 3110 | 105989.9 | 127966.7 | 3160 | 13776.0 | 127966.7 | B31.3 |
| 2(SUS) | 1760 | 28433.7 | 127966.7 | 3210 | 35742.5 | 127966.7 | B31.3 |
| 2(SUS) | 3210 | 35742.5 | 127966.7 | 3260 | 52771.5 | 127966.7 | B31.3 |
| 2(SUS) | 3260 | 52771.5 | 127966.7 | 3310 | 41025.6 | 127966.7 | B31.3 |
| 2(SUS) | 3310 | 41025.6 | 127966.7 | 3360 | 55227.2 | 127966.7 | B31.3 |
| 2(SUS) | 3360 | 55232.1 | 127966.7 | 3410 | 41393.5 | 127966.7 | B31.3 |
| 2(SUS) | 3410 | 41393.5 | 127966.7 | 3460 | 57941.1 | 127966.7 | B31.3 |
| 2(SUS) | 3460 | 57941.1 | 127966.7 | 3510 | 15509.5 | 127966.7 | B31.3 |

7.3.1.2 RESTRAIN REPORT

Supports are provided to the piping to resist various loads.

Table 7.3.1.2 Restrain report

| Node | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. | |
|------|-------|--------|-------|---------|---------|---------|----------|
| 10 | 0 | 0 | 0 | 0 | 0 | 0 | Flex X |
| 10 | 0 | 0 | 0 | 12946 | 0 | 0 | Rigid RX |
| 10 | 0 | 0 | 0 | 0 | 0 | 0 | Rigid Z |
| 10 | 0 | 0 | 0 | 0 | 0 | -293 | Flex RZ |
| 10 | 0 | -3455 | 0 | 0 | 0 | 0 | Rigid Y |
| 10 | 0 | 0 | 0 | 0 | -0 | 0 | Flex RY |
| 110 | 0 | -16827 | 0 | 0 | 0 | 0 | Rigid +Y |
| 211 | 0 | -16294 | 0 | 0 | 0 | 0 | Rigid +Y |
| 310 | 0 | -16725 | 0 | 0 | 0 | 0 | Rigid +Y |
| 510 | 0 | -15777 | 0 | 0 | 0 | 0 | Rigid +Y |
| 560 | 0 | -17347 | 0 | 0 | 0 | 0 | Rigid +Y |
| 660 | 0 | -15567 | 0 | 0 | 0 | 0 | Rigid +Y |
| 860 | 0 | -17083 | 0 | 0 | 0 | 0 | Rigid +Y |

| Node | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. | |
|-------------|----------|---------------|----------|------------|------------|----------|-----------------|
| 910 | 0 | -16093 | 0 | 0 | 0 | 0 | Rigid +Y |
| 961 | 0 | -15109 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1060 | 0 | -17814 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1160 | 0 | -15285 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1260 | 0 | -16858 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1310 | 0 | -14962 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1410 | 0 | -14966 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1510 | 0 | -17128 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1610 | 0 | -16977 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1710 | 0 | -15546 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1720 | 0 | -21654 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1810 | 0 | -15966 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1910 | 0 | -16770 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1960 | 0 | -16651 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2060 | 0 | -16538 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2160 | 0 | -16120 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2210 | 0 | -15457 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2310 | 0 | -14169 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2360 | 0 | -16433 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2411 | 0 | -14430 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2510 | 0 | -12499 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2660 | 0 | -14306 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2710 | 0 | -13525 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2810 | 0 | -15120 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2910 | 0 | -13344 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3010 | 0 | -13650 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3110 | 0 | -13071 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3260 | 0 | -14079 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3310 | 0 | -12154 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3360 | 0 | -14940 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3460 | 0 | -14709 | 0 | 0 | 0 | 0 | Rigid +Y |

7.3.1.3 Stress Report

Piping Code: B31.3 = B31.3 -2010,

CODE STRESS CHECK PASSED : LOADCASE 2 (SUS) W+P1

Highest Stresses: (KPa)

Ratio (%): 78.3 @Node 2810

| | | |
|-----------------------|----------|----------------------------|
| Code Stress: | 100228.1 | Allowable Stress: 127966.7 |
| Axial Stress: | 17553.4 | @Node 211 |
| Bending Stress: | 119321.7 | @Node 2818 |
| Torsion Stress: | 19996.3 | @Node 1780 |
| Hoop Stress: | 32222.2 | @Node 58 |
| Max Stress Intensity: | 133049.0 | @Node 2818 |

Table 7.3.1.3: Stress Report

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 10 | 15841.3 | 2187.9 | 14954.9 | 32222.2 | 43960.5 | 1.000 | 1.000 | 34923.5 | 127966.7 | 27.3 | B31.3 |
| 58 | 15841.3 | 21162.8 | -14954.9 | 32222.2 | 50912.4 | 1.000 | 1.000 | 47580.5 | 127966.7 | 37.2 | B31.3 |
| | | | | | | | | | | | |
| 58 | 15841.3 | 47677.9 | 14954.9 | 32222.2 | 70208.9 | 2.256 | 1.880 | 59641.7 | 127966.7 | 46.6 | B31.3 |
| 59 | 15916.7 | 63930.8 | -10798.8 | 32222.2 | 81930.9 | 2.256 | 1.880 | 67417.8 | 127966.7 | 52.7 | B31.3 |
| | | | | | | | | | | | |
| 59 | 15916.7 | 63930.8 | 10798.8 | 32222.2 | 82716.8 | 2.256 | 1.880 | 67417.8 | 127966.7 | 52.7 | B31.3 |
| 60 | 15753.6 | 78039.4 | 688.0 | 32222.2 | 93314.9 | 2.256 | 1.880 | 74295.9 | 127966.7 | 58.1 | B31.3 |
| | | | | | | | | | | | |
| 60 | 15753.6 | 39220.9 | -688.0 | 32222.2 | 54991.7 | 1.000 | 1.000 | 54991.7 | 127966.7 | 43.0 | B31.3 |
| 110 | 15753.6 | 48767.5 | 688.0 | 32222.2 | 64047.6 | 1.000 | 1.000 | 64535.8 | 127966.7 | 50.4 | B31.3 |
| | | | | | | | | | | | |
| 110 | 15753.6 | 48767.5 | -688.0 | 32222.2 | 64535.8 | 1.000 | 1.000 | 64535.8 | 127966.7 | 50.4 | B31.3 |
| 120 | 15753.6 | 13517.8 | 688.0 | 32222.2 | 36095.8 | 1.000 | 1.000 | 29303.7 | 127966.7 | 22.9 | B31.3 |
| | | | | | | | | | | | |
| 120 | 15753.6 | 13517.8 | -688.0 | 32222.2 | 36089.4 | 1.000 | 1.000 | 29303.7 | 127966.7 | 22.9 | B31.3 |
| 160 | 15753.6 | 76750.3 | 688.0 | 32222.2 | 92026.0 | 1.000 | 1.000 | 92514.1 | 127966.7 | 72.3 | B31.3 |
| | | | | | | | | | | | |
| 160 | 15753.6 | 76750.3 | -688.0 | 32222. | 92514.1 | 1.00 | 1.00 | 92514.1 | 127966.7 | 72.3 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| | | | | 2 | | 0 | 0 | | | | |
| 210 | 17084.1 | 71809.9 | 3151.7 | 32222.2 | 86393.5 | 2.256 | 1.880 | 71221.0 | 127966.7 | 55.7 | B31.3 |
| | | | | | | | | | | | |
| 210 | 17084.1 | 31839.6 | -3151.7 | 32222.2 | 49478.3 | 1.000 | 1.000 | 49328.2 | 127966.7 | 38.5 | B31.3 |
| 211 | 17553.4 | 20798.9 | 3151.7 | 32222.2 | 41053.8 | 1.000 | 1.000 | 38866.9 | 127966.7 | 30.4 | B31.3 |
| | | | | | | | | | | | |
| 211 | 15633.0 | 20798.9 | -3151.7 | 32222.2 | 39585.6 | 1.000 | 1.000 | 36973.2 | 127966.7 | 28.9 | B31.3 |
| 220 | 15811.8 | 16601.5 | 3151.7 | 32222.2 | 38011.4 | 1.000 | 1.000 | 33020.5 | 127966.7 | 25.8 | B31.3 |
| | | | | | | | | | | | |
| 220 | 15811.8 | 16601.5 | -3151.7 | 32222.2 | 37831.8 | 1.000 | 1.000 | 33020.5 | 127966.7 | 25.8 | B31.3 |
| 260 | 15527.0 | 11988.6 | -3975.2 | 32222.2 | 37625.1 | 2.256 | 1.880 | 25775.2 | 127966.7 | 20.1 | B31.3 |
| | | | | | | | | | | | |
| 260 | 15527.0 | 5922.6 | 3975.2 | 32222.2 | 37024.3 | 1.000 | 1.000 | 22875.6 | 127966.7 | 17.9 | B31.3 |
| 310 | 15527.0 | 68755.3 | -3975.2 | 32222.2 | 84621.5 | 1.000 | 1.000 | 84656.5 | 127966.7 | 66.2 | B31.3 |
| | | | | | | | | | | | |
| 310 | 15527.0 | 68755.3 | 3975.2 | 32222.2 | 84656.5 | 1.000 | 1.000 | 84656.5 | 127966.7 | 66.2 | B31.3 |
| 360 | 14655.8 | 16610.6 | -3220.3 | 32222.2 | 37744.8 | 2.256 | 1.880 | 27868.2 | 127966.7 | 21.8 | B31.3 |
| | | | | | | | | | | | |
| 360 | 14655.8 | 8703.6 | 3220.3 | 32222.2 | 36914.3 | 1.000 | 1.000 | 24231.0 | 127966.7 | 18.9 | B31.3 |
| 410 | 15440.5 | 16303.2 | -1280.6 | 32222.2 | 36438.2 | 2.256 | 1.880 | 27786.1 | 127966.7 | 21.7 | B31.3 |
| | | | | | | | | | | | |
| 410 | 15440.5 | 8028.9 | 1280.6 | 32222.2 | 36151.8 | 1.000 | 1.000 | 23608.6 | 127966.7 | 18.4 | B31.3 |
| 460 | 15440.5 | 6327.6 | -1280.6 | 32222.2 | 36133.5 | 1.000 | 1.000 | 21918.2 | 127966.7 | 17.1 | B31.3 |
| | | | | | | | | | | | |
| 460 | 15440.5 | 6327.6 | 1280.6 | 32222.2 | 36134.8 | 1.000 | 1.000 | 21918.2 | 127966.7 | 17.1 | B31.3 |
| 470 | 15440.5 | 15368.9 | -1280.6 | 32222.2 | 36358.7 | 1.000 | 1.000 | 30915.6 | 127966.7 | 24.2 | B31.3 |
| | | | | | | | | | | | |
| 470 | 15440.5 | 15368.9 | 1280.6 | 32222.2 | 36369.4 | 1.000 | 1.000 | 30915.6 | 127966.7 | 24.2 | B31.3 |
| 480 | 15440.5 | 60152.3 | -1280.6 | 32222.2 | 75774.0 | 1.000 | 1.000 | 75636.1 | 127966.7 | 59.1 | B31.3 |
| | | | | | | | | | | | |
| 480 | 15440.5 | 60152.3 | 1280.6 | 32222. | 75636.1 | 1.00 | 1.00 | 75636.1 | 127966.7 | 59.1 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| | | | | 2 | | 0 | 0 | | | | |
| 490 | 15440.5 | 31564.1 | -1280.6 | 32222.2 | 47429.5 | 1.000 | 1.000 | 47074.3 | 127966.7 | 36.8 | B31.3 |
| | | | | | | | | | | | |
| 490 | 15440.5 | 31564.1 | 1280.6 | 32222.2 | 47493.0 | 1.000 | 1.000 | 47074.3 | 127966.7 | 36.8 | B31.3 |
| 518 | 15440.5 | 16728.2 | -1280.6 | 32222.2 | 36486.2 | 1.000 | 1.000 | 32270.4 | 127966.7 | 25.2 | B31.3 |
| | | | | | | | | | | | |
| 518 | 15440.5 | 37734.8 | 1280.6 | 32222.2 | 53236.9 | 2.256 | 1.880 | 43816.5 | 127966.7 | 34.2 | B31.3 |
| 519 | 15925.2 | 31216.6 | -784.5 | 32222.2 | 47440.6 | 2.256 | 1.880 | 39368.9 | 127966.7 | 30.8 | B31.3 |
| | | | | | | | | | | | |
| 519 | 15925.2 | 31216.6 | 784.5 | 32222.2 | 47416.5 | 2.256 | 1.880 | 39368.9 | 127966.7 | 30.8 | B31.3 |
| 520 | 16219.0 | 27839.1 | 204.4 | 32222.2 | 44558.0 | 2.256 | 1.880 | 37100.7 | 127966.7 | 29.0 | B31.3 |
| | | | | | | | | | | | |
| 520 | 16219.0 | 12429.0 | -204.4 | 32222.2 | 36023.9 | 1.000 | 1.000 | 28650.9 | 127966.7 | 22.4 | B31.3 |
| 530 | 15440.5 | 3357.0 | -1733.6 | 32222.2 | 36189.9 | 2.256 | 1.880 | 18289.8 | 127966.7 | 14.3 | B31.3 |
| | | | | | | | | | | | |
| 530 | 15440.5 | 1515.8 | 1733.6 | 32222.2 | 36174.0 | 1.000 | 1.000 | 17307.1 | 127966.7 | 13.5 | B31.3 |
| 540 | 14052.9 | 53723.7 | -430.8 | 32222.2 | 70695.0 | 2.256 | 1.880 | 54352.6 | 127966.7 | 42.5 | B31.3 |
| | | | | | | | | | | | |
| 540 | 14052.9 | 23887.1 | 430.8 | 32222.2 | 41661.6 | 1.000 | 1.000 | 37949.8 | 127966.7 | 29.7 | B31.3 |
| 550 | 15440.5 | 74361.2 | -1280.6 | 32222.2 | 89976.1 | 2.256 | 1.880 | 71257.4 | 127966.7 | 55.7 | B31.3 |
| | | | | | | | | | | | |
| 550 | 15440.5 | 32967.8 | 1280.6 | 32222.2 | 48783.2 | 1.000 | 1.000 | 48476.0 | 127966.7 | 37.9 | B31.3 |
| 560 | 15440.5 | 37212.3 | -1280.6 | 32222.2 | 52852.9 | 1.000 | 1.000 | 52715.1 | 127966.7 | 41.2 | B31.3 |
| | | | | | | | | | | | |
| 560 | 15440.5 | 37212.3 | 1280.6 | 32222.2 | 52715.1 | 1.000 | 1.000 | 52715.1 | 127966.7 | 41.2 | B31.3 |
| 610 | 15440.5 | 25278.7 | -1280.6 | 32222.2 | 41649.8 | 1.000 | 1.000 | 40799.6 | 127966.7 | 31.9 | B31.3 |
| | | | | | | | | | | | |
| 610 | 15495.9 | 25278.7 | 1280.6 | 32222.2 | 41728.9 | 1.000 | 1.000 | 40854.9 | 127966.7 | 31.9 | B31.3 |
| 660 | 15495.9 | 32051.7 | -1280.6 | 32222.2 | 47859.2 | 1.000 | 1.000 | 47616.5 | 127966.7 | 37.2 | B31.3 |
| | | | | | | | | | | | |
| 660 | 15495.9 | 32051.7 | 1280.6 | 32222. | 47885.9 | 1.00 | 1.00 | 47616.5 | 127966.7 | 37.2 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| | | | | 2 | | 0 | 0 | | | | |
| 710 | 15495.9 | 30908.9 | -1280.6 | 32222.2 | 46810.3 | 1.000 | 1.000 | 46475.5 | 127966.7 | 36.3 | B31.3 |
| | | | | | | | | | | | |
| 710 | 15495.9 | 30908.9 | 1280.6 | 32222.2 | 46837.0 | 1.000 | 1.000 | 46475.5 | 127966.7 | 36.3 | B31.3 |
| 760 | 16125.7 | 6247.4 | -73.3 | 32222.2 | 36019.3 | 2.256 | 1.880 | 20811.8 | 127966.7 | 16.3 | B31.3 |
| | | | | | | | | | | | |
| 760 | 16125.7 | 3115.9 | 73.3 | 32222.2 | 36019.2 | 1.000 | 1.000 | 19242.1 | 127966.7 | 15.0 | B31.3 |
| 770 | 15477.7 | 2937.0 | -73.3 | 32222.2 | 36019.2 | 1.000 | 1.000 | 18415.2 | 127966.7 | 14.4 | B31.3 |
| | | | | | | | | | | | |
| 770 | 15477.7 | 2937.0 | 73.3 | 32222.2 | 36019.2 | 1.000 | 1.000 | 18415.2 | 127966.7 | 14.4 | B31.3 |
| 810 | 15442.7 | 6821.8 | 122.3 | 32222.2 | 36020.0 | 2.256 | 1.880 | 20560.5 | 127966.7 | 16.1 | B31.3 |
| | | | | | | | | | | | |
| 810 | 15442.7 | 3024.4 | -122.3 | 32222.2 | 36019.8 | 1.000 | 1.000 | 18468.8 | 127966.7 | 14.4 | B31.3 |
| 860 | 15442.7 | 49279.6 | 122.3 | 32222.2 | 64856.3 | 1.000 | 1.000 | 64722.8 | 127966.7 | 50.6 | B31.3 |
| | | | | | | | | | | | |
| 860 | 15442.7 | 49279.6 | -122.3 | 32222.2 | 64722.8 | 1.000 | 1.000 | 64722.8 | 127966.7 | 50.6 | B31.3 |
| 870 | 15442.7 | 14128.5 | 10831.0 | 32222.2 | 43904.3 | 1.000 | 1.000 | 36687.6 | 127966.7 | 28.7 | B31.3 |
| | | | | | | | | | | | |
| 870 | 15442.7 | 36665.3 | -122.3 | 32222.2 | 52108.6 | 1.000 | 1.000 | 52108.6 | 127966.7 | 40.7 | B31.3 |
| 910 | 15442.7 | 47654.0 | 122.3 | 32222.2 | 63230.6 | 1.000 | 1.000 | 63097.1 | 127966.7 | 49.3 | B31.3 |
| | | | | | | | | | | | |
| 910 | 15495.6 | 47654.0 | -122.3 | 32222.2 | 63150.1 | 1.000 | 1.000 | 63150.1 | 127966.7 | 49.3 | B31.3 |
| 960 | 15751.2 | 3522.8 | -154.3 | 32222.2 | 36020.3 | 2.256 | 1.880 | 18395.9 | 127966.7 | 14.4 | B31.3 |
| | | | | | | | | | | | |
| 960 | 15751.2 | 1566.0 | 154.3 | 32222.2 | 36020.1 | 1.000 | 1.000 | 17320.0 | 127966.7 | 13.5 | B31.3 |
| 961 | 15773.6 | 1535.1 | -154.3 | 32222.2 | 36020.2 | 1.000 | 1.000 | 17311.4 | 127966.7 | 13.5 | B31.3 |
| | | | | | | | | | | | |
| 961 | 13553.0 | 1535.1 | 154.3 | 32222.2 | 36020.3 | 1.000 | 1.000 | 15091.2 | 127966.7 | 11.8 | B31.3 |
| 1010 | 15495.6 | 3625.9 | -299.3 | 32222.2 | 36024.2 | 2.256 | 1.880 | 18224.9 | 127966.7 | 14.2 | B31.3 |
| | | | | | | | | | | | |
| 1010 | 15495.6 | 1614.5 | 299.3 | 32222. | 36023.6 | 1.00 | 1.00 | 17120.6 | 127966.7 | 13.4 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| | | | | 2 | | 0 | 0 | | | | |
| 1060 | 15495.6 | 57243.4 | -299.3 | 32222.2 | 72769.1 | 1.000 | 1.000 | 72741.5 | 127966.7 | 56.8 | B31.3 |
| | | | | | | | | | | | |
| 1060 | 15495.6 | 57243.4 | 299.3 | 32222.2 | 72741.5 | 1.000 | 1.000 | 72741.5 | 127966.7 | 56.8 | B31.3 |
| | | | | | | | | | | | |
| 1110 | 15495.6 | 44599.3 | -299.3 | 32222.2 | 60125.6 | 1.000 | 1.000 | 60097.9 | 127966.7 | 47.0 | B31.3 |
| | | | | | | | | | | | |
| 1110 | 15495.6 | 44599.3 | 299.3 | 32222.2 | 60097.9 | 1.000 | 1.000 | 60097.9 | 127966.7 | 47.0 | B31.3 |
| | | | | | | | | | | | |
| 1160 | 15495.6 | 46262.1 | -299.3 | 32222.2 | 61788.2 | 1.000 | 1.000 | 61760.6 | 127966.7 | 48.3 | B31.3 |
| | | | | | | | | | | | |
| 1160 | 15495.6 | 46262.1 | 299.3 | 32222.2 | 61760.6 | 1.000 | 1.000 | 61760.6 | 127966.7 | 48.3 | B31.3 |
| | | | | | | | | | | | |
| 1210 | 15495.6 | 11643.8 | -299.3 | 32222.2 | 36029.6 | 1.000 | 1.000 | 27146.0 | 127966.7 | 21.2 | B31.3 |
| | | | | | | | | | | | |
| 1210 | 15495.6 | 11643.8 | 299.3 | 32222.2 | 36029.6 | 1.000 | 1.000 | 27146.0 | 127966.7 | 21.2 | B31.3 |
| | | | | | | | | | | | |
| 1260 | 15495.6 | 55650.3 | -299.3 | 32222.2 | 71176.1 | 1.000 | 1.000 | 71148.5 | 127966.7 | 55.6 | B31.3 |
| | | | | | | | | | | | |
| 1260 | 15495.6 | 55650.3 | 299.3 | 32222.2 | 71148.5 | 1.000 | 1.000 | 71148.5 | 127966.7 | 55.6 | B31.3 |
| | | | | | | | | | | | |
| 1310 | 15495.6 | 48730.1 | -299.3 | 32222.2 | 64256.2 | 1.000 | 1.000 | 64228.5 | 127966.7 | 50.2 | B31.3 |
| | | | | | | | | | | | |
| 1310 | 15495.6 | 48730.1 | 299.3 | 32222.2 | 64228.5 | 1.000 | 1.000 | 64228.5 | 127966.7 | 50.2 | B31.3 |
| | | | | | | | | | | | |
| 1360 | 15495.6 | 82574.6 | -299.3 | 32222.2 | 98099.7 | 2.040 | 2.387 | 77428.9 | 127966.7 | 60.5 | B31.3 |
| | | | | | | | | | | | |
| 1360 | 15481.2 | 79754.5 | -10831.0 | 32222.2 | 97668.3 | 2.040 | 2.387 | 78351.1 | 127966.7 | 61.2 | B31.3 |
| | | | | | | | | | | | |
| 1410 | 15481.2 | 68910.8 | 10831.0 | 32222.2 | 87182.5 | 1.000 | 1.000 | 87127.9 | 127966.7 | 68.1 | B31.3 |
| | | | | | | | | | | | |
| 1410 | 15481.2 | 68910.8 | -10831.0 | 32222.2 | 87127.9 | 1.000 | 1.000 | 87127.9 | 127966.7 | 68.1 | B31.3 |
| | | | | | | | | | | | |
| 1460 | 15481.2 | 4642.4 | 10831.0 | 32222.2 | 41325.9 | 1.000 | 1.000 | 29566.9 | 127966.7 | 23.1 | B31.3 |
| | | | | | | | | | | | |
| 1460 | 15481.2 | 4642.4 | -10831.0 | 32222.2 | 41338.2 | 1.000 | 1.000 | 29566.9 | 127966.7 | 23.1 | B31.3 |
| | | | | | | | | | | | |
| 1510 | 15481.2 | 13990.9 | 10831.0 | 32222.2 | 43855.8 | 1.000 | 1.000 | 36576.6 | 127966.7 | 28.6 | B31.3 |
| | | | | | | | | | | | |
| 1510 | 15481.2 | 13990.9 | - | 32222. | 43877.2 | 1.00 | 1.00 | 36576.6 | 127966.7 | 28.6 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| | | | 10831.0 | 2 | | 0 | 0 | | | | |
| 1518 | 15481.2 | | | | | | | | | | |
| | | | | | | | | | | | |
| 1518 | 15481.2 | 26810.7 | -10831.0 | 32222.2 | 50095.1 | 2.256 | 1.880 | 41663.4 | 127966.7 | 32.6 | B31.3 |
| 1519 | 15492.9 | 47839.5 | 2736.9 | 32222.2 | 63601.5 | 2.256 | 1.880 | 51663.4 | 127966.7 | 40.4 | B31.3 |
| | | | | | | | | | | | |
| 1519 | 15492.9 | 47839.5 | -2736.9 | 32222.2 | 63568.6 | 2.256 | 1.880 | 51663.4 | 127966.7 | 40.4 | B31.3 |
| 1520 | 15514.3 | 41041.8 | -6965.6 | 32222.2 | 58237.1 | 2.256 | 1.880 | 48346.3 | 127966.7 | 37.8 | B31.3 |
| | | | | | | | | | | | |
| 1520 | 15514.3 | 21757.3 | 6965.6 | 32222.2 | 43662.2 | 1.000 | 1.000 | 39790.1 | 127966.7 | 31.1 | B31.3 |
| 1530 | 15481.2 | 13395.8 | -15950.1 | 32222.2 | 48280.5 | 2.256 | 1.880 | 40857.2 | 127966.7 | 31.9 | B31.3 |
| | | | | | | | | | | | |
| 1530 | 15481.2 | 7125.8 | 15950.1 | 32222.2 | 46190.3 | 1.000 | 1.000 | 39098.6 | 127966.7 | 30.6 | B31.3 |
| 1532 | 15481.2 | 5229.4 | -15950.1 | 32222.2 | 45629.9 | 1.000 | 1.000 | 38033.7 | 127966.7 | 29.7 | B31.3 |
| | | | | | | | | | | | |
| 1532 | 15481.2 | 5229.4 | 15950.1 | 32222.2 | 45646.7 | 1.000 | 1.000 | 38033.7 | 127966.7 | 29.7 | B31.3 |
| 1540 | 15504.6 | 62115.9 | 8851.9 | 32222.2 | 79623.4 | 2.256 | 1.880 | 64566.1 | 127966.7 | 50.5 | B31.3 |
| | | | | | | | | | | | |
| 1540 | 15504.6 | 33042.1 | -8851.9 | 32222.2 | 52718.2 | 1.000 | 1.000 | 51674.0 | 127966.7 | 40.4 | B31.3 |
| 1550 | 15481.2 | 23480.7 | 1098.1 | 32222.2 | 40030.2 | 2.256 | 1.880 | 33164.6 | 127966.7 | 25.9 | B31.3 |
| | | | | | | | | | | | |
| 1550 | 15481.2 | 12376.9 | -1098.1 | 32222.2 | 36175.0 | 1.000 | 1.000 | 27944.6 | 127966.7 | 21.8 | B31.3 |
| 1560 | 15481.2 | 56242.8 | 1098.1 | 32222.2 | 71814.1 | 1.000 | 1.000 | 71757.7 | 127966.7 | 56.1 | B31.3 |
| | | | | | | | | | | | |
| 1560 | 15481.2 | 56242.8 | -1098.1 | 32222.2 | 71757.7 | 1.000 | 1.000 | 71757.7 | 127966.7 | 56.1 | B31.3 |
| 1610 | 15481.2 | 53487.0 | 1098.1 | 32222.2 | 69059.6 | 1.000 | 1.000 | 69003.2 | 127966.7 | 53.9 | B31.3 |
| | | | | | | | | | | | |
| 1610 | 15481.2 | 53487.0 | -1098.1 | 32222.2 | 69003.2 | 1.000 | 1.000 | 69003.2 | 127966.7 | 53.9 | B31.3 |
| 1660 | 15481.2 | 33524.3 | 1098.1 | 32222.2 | 49190.5 | 1.000 | 1.000 | 49054.8 | 127966.7 | 38.3 | B31.3 |
| | | | | | | | | | | | |
| 1660 | 15481.2 | 33524.3 | -1098.1 | 32222.2 | 49226.9 | 1.000 | 1.000 | 49054.8 | 127966.7 | 38.3 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 1710 | 15481.2 | 57367.0 | 1098.1 | 32222.2 | 72937.8 | 1.000 | 1.000 | 72881.3 | 127966.7 | 57.0 | B31.3 |
| | | | | | | | | | | | |
| 1710 | 15481.2 | 57367.0 | -1098.1 | 32222.2 | 72881.3 | 1.000 | 1.000 | 72881.3 | 127966.7 | 57.0 | B31.3 |
| 1711 | 15481.2 | 21520.1 | 1098.1 | 32222.2 | 38389.9 | 1.000 | 1.000 | 37066.4 | 127966.7 | 29.0 | B31.3 |
| | | | | | | | | | | | |
| 1711 | 15501.8 | 21520.1 | -1098.1 | 32222.2 | 38420.2 | 1.000 | 1.000 | 37087.0 | 127966.7 | 29.0 | B31.3 |
| 1720 | 15501.8 | 30790.4 | 1098.1 | 32222.2 | 46672.8 | 1.000 | 1.000 | 46344.3 | 127966.7 | 36.2 | B31.3 |
| | | | | | | | | | | | |
| 1720 | 15501.8 | 30790.4 | -1098.1 | 32222.2 | 46687.9 | 1.000 | 1.000 | 46344.3 | 127966.7 | 36.2 | B31.3 |
| 1760 | 15501.8 | 40365.0 | 1098.1 | 32222.2 | 55925.3 | 2.040 | 2.387 | 45828.3 | 127966.7 | 35.8 | B31.3 |
| | | | | | | | | | | | |
| 1760 | 15509.5 | 11804.7 | -8433.8 | 32222.2 | 41076.3 | 2.040 | 2.387 | 29632.3 | 127966.7 | 23.2 | B31.3 |
| 1761 | 15509.5 | 81456.5 | 8433.8 | 32222.2 | 98422.1 | 1.000 | 1.000 | 98422.1 | 127966.7 | 76.9 | B31.3 |
| | | | | | | | | | | | |
| 1761 | 15509.5 | 81456.5 | -8433.8 | 32222.2 | 98422.1 | 1.000 | 1.000 | 98422.1 | 127966.7 | 76.9 | B31.3 |
| 1768 | 15509.5 | 4843.4 | 8433.8 | 32222.2 | 39601.6 | 1.000 | 1.000 | 26434.0 | 127966.7 | 20.7 | B31.3 |
| | | | | | | | | | | | |
| 1768 | 15509.5 | 9106.0 | -8433.8 | 32222.2 | 40409.9 | 2.256 | 1.880 | 27991.9 | 127966.7 | 21.9 | B31.3 |
| 1769 | 15509.3 | 29568.6 | 4164.2 | 32222.2 | 46830.3 | 2.256 | 1.880 | 38595.1 | 127966.7 | 30.2 | B31.3 |
| | | | | | | | | | | | |
| 1769 | 15509.3 | 29568.6 | -4164.2 | 32222.2 | 46830.5 | 2.256 | 1.880 | 38595.1 | 127966.7 | 30.2 | B31.3 |
| 1770 | 15509.2 | 32237.0 | -2654.0 | 32222.2 | 48414.5 | 2.256 | 1.880 | 40040.4 | 127966.7 | 31.3 | B31.3 |
| | | | | | | | | | | | |
| 1770 | 15509.2 | 17148.2 | 2654.0 | 32222.2 | 37647.6 | 1.000 | 1.000 | 33086.0 | 127966.7 | 25.9 | B31.3 |
| 1780 | 15509.5 | 3239.1 | -19996.3 | 32222.2 | 48532.7 | 2.256 | 1.880 | 43831.6 | 127966.7 | 34.3 | B31.3 |
| | | | | | | | | | | | |
| 1780 | 15509.5 | 1721.7 | 19996.3 | 32222.2 | 48103.0 | 1.000 | 1.000 | 43546.8 | 127966.7 | 34.0 | B31.3 |
| 1781 | 15509.5 | 14441.3 | -19996.3 | 32222.2 | 52414.0 | 1.000 | 1.000 | 49964.6 | 127966.7 | 39.0 | B31.3 |
| | | | | | | | | | | | |
| 1781 | 15509.5 | 14441.3 | 19996.3 | 32222.2 | 52414.0 | 1.000 | 1.000 | 49964.6 | 127966.7 | 39.0 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 1790 | 15509.7 | 77538.3 | 4693.4 | 32222.2 | 93519.8 | 2.256 | 1.880 | 74259.0 | 127966.7 | 58.0 | B31.3 |
| | | | | | | | | | | | |
| 1790 | 15509.7 | 41246.1 | -4693.4 | 32222.2 | 57526.7 | 1.000 | 1.000 | 57526.7 | 127966.7 | 45.0 | B31.3 |
| 1800 | 15509.5 | 6269.5 | 0.0 | 32222.2 | 36018.9 | 2.256 | 1.880 | 20211.6 | 127966.7 | 15.8 | B31.3 |
| | | | | | | | | | | | |
| 1800 | 15509.5 | 3334.5 | 0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 18844.0 | 127966.7 | 14.7 | B31.3 |
| 1810 | 15509.5 | 1212.5 | -0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 16722.0 | 127966.7 | 13.1 | B31.3 |
| | | | | | | | | | | | |
| 1810 | 15509.5 | 1212.5 | -0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 16722.0 | 127966.7 | 13.1 | B31.3 |
| 1860 | 15509.5 | 32535.5 | 0.0 | 32222.2 | 48202.4 | 1.000 | 1.000 | 48044.9 | 127966.7 | 37.5 | B31.3 |
| | | | | | | | | | | | |
| 1860 | 15509.5 | 32535.5 | 0.0 | 32222.2 | 48202.4 | 1.000 | 1.000 | 48044.9 | 127966.7 | 37.5 | B31.3 |
| 1910 | 15509.5 | 61422.9 | -0.0 | 32222.2 | 76932.4 | 1.000 | 1.000 | 76932.4 | 127966.7 | 60.1 | B31.3 |
| | | | | | | | | | | | |
| 1910 | 15509.5 | 61422.9 | 0.0 | 32222.2 | 76932.4 | 1.000 | 1.000 | 76932.4 | 127966.7 | 60.1 | B31.3 |
| 1960 | 15509.5 | 44341.8 | -0.0 | 32222.2 | 59851.2 | 1.000 | 1.000 | 59851.2 | 127966.7 | 46.8 | B31.3 |
| | | | | | | | | | | | |
| 1960 | 15509.5 | 44341.8 | 0.0 | 32222.2 | 59851.2 | 1.000 | 1.000 | 59851.2 | 127966.7 | 46.8 | B31.3 |
| 2010 | 15509.5 | 10484.4 | 0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 25993.9 | 127966.7 | 20.3 | B31.3 |
| | | | | | | | | | | | |
| 2010 | 15509.5 | 10484.4 | -0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 25993.9 | 127966.7 | 20.3 | B31.3 |
| 2060 | 15509.5 | 44603.0 | 0.0 | 32222.2 | 60112.4 | 1.000 | 1.000 | 60112.4 | 127966.7 | 47.0 | B31.3 |
| | | | | | | | | | | | |
| 2060 | 15509.5 | 44603.0 | 0.0 | 32222.2 | 60112.4 | 1.000 | 1.000 | 60112.4 | 127966.7 | 47.0 | B31.3 |
| 2110 | 15509.5 | 31597.8 | 0.0 | 32222.2 | 47332.2 | 1.000 | 1.000 | 47107.2 | 127966.7 | 36.8 | B31.3 |
| | | | | | | | | | | | |
| 2110 | 15509.5 | 31597.8 | 0.0 | 32222.2 | 47332.2 | 1.000 | 1.000 | 47107.2 | 127966.7 | 36.8 | B31.3 |
| 2160 | 15509.5 | 43704.9 | -0.0 | 32222.2 | 59214.3 | 1.000 | 1.000 | 59214.3 | 127966.7 | 46.3 | B31.3 |
| | | | | | | | | | | | |
| 2160 | 15509.5 | 43704.9 | 0.0 | 32222.2 | 59214.3 | 1.000 | 1.000 | 59214.3 | 127966.7 | 46.3 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 2210 | 15509.5 | 42673.7 | 0.0 | 32222.2 | 58183.2 | 1.000 | 1.000 | 58183.2 | 127966.7 | 45.5 | B31.3 |
| | | | | | | | | | | | |
| 2210 | 15509.5 | 42673.7 | 0.0 | 32222.2 | 58183.2 | 1.000 | 1.000 | 58183.2 | 127966.7 | 45.5 | B31.3 |
| 2260 | 15509.5 | 31113.2 | 0.0 | 32222.2 | 46882.5 | 1.000 | 1.000 | 46622.6 | 127966.7 | 36.4 | B31.3 |
| | | | | | | | | | | | |
| 2260 | 15509.5 | 31113.2 | -0.0 | 32222.2 | 46882.5 | 1.000 | 1.000 | 46622.6 | 127966.7 | 36.4 | B31.3 |
| 2310 | 15509.5 | 36216.6 | 0.0 | 32222.2 | 51726.0 | 1.000 | 1.000 | 51726.0 | 127966.7 | 40.4 | B31.3 |
| | | | | | | | | | | | |
| 2310 | 15509.5 | 36216.6 | -0.0 | 32222.2 | 51726.0 | 1.000 | 1.000 | 51726.0 | 127966.7 | 40.4 | B31.3 |
| 2360 | 15509.5 | 49541.4 | 0.0 | 32222.2 | 65050.8 | 1.000 | 1.000 | 65050.8 | 127966.7 | 50.8 | B31.3 |
| | | | | | | | | | | | |
| 2360 | 15509.5 | 49541.4 | -0.0 | 32222.2 | 65050.8 | 1.000 | 1.000 | 65050.8 | 127966.7 | 50.8 | B31.3 |
| 2410 | 15509.5 | 41735.7 | 0.0 | 32222.2 | 57245.2 | 1.000 | 1.000 | 57245.2 | 127966.7 | 44.7 | B31.3 |
| | | | | | | | | | | | |
| 2410 | 15509.5 | 41735.7 | -0.0 | 32222.2 | 57245.2 | 1.000 | 1.000 | 57245.2 | 127966.7 | 44.7 | B31.3 |
| 2411 | 15509.5 | 35054.1 | 0.0 | 32222.2 | 50563.5 | 1.000 | 1.000 | 50563.5 | 127966.7 | 39.5 | B31.3 |
| | | | | | | | | | | | |
| 2411 | 15509.5 | 35054.1 | 0.0 | 32222.2 | 50563.5 | 1.000 | 1.000 | 50563.5 | 127966.7 | 39.5 | B31.3 |
| 2460 | 15509.5 | 0.0 | -0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 15509.5 | 127966.7 | 12.1 | B31.3 |
| | | | | | | | | | | | |
| 1360 | 14471.9 | 81132.4 | 4.4 | 28750.0 | 95604.3 | 2.040 | 2.387 | 75321.2 | 127966.7 | 58.9 | B31.3 |
| 2510 | 14471.9 | 51093.4 | -5.2 | 28750.0 | 64173.6 | 1.000 | 1.000 | 65565.3 | 127966.7 | 51.2 | B31.3 |
| | | | | | | | | | | | |
| 2510 | 14471.9 | 51093.4 | 5.2 | 28750.0 | 65565.3 | 1.000 | 1.000 | 65565.3 | 127966.7 | 51.2 | B31.3 |
| 2520 | 14471.9 | 17011.5 | -5.2 | 28750.0 | 32622.9 | 1.000 | 1.000 | 31483.5 | 127966.7 | 24.6 | B31.3 |
| | | | | | | | | | | | |
| 2520 | 14471.9 | 17011.5 | 5.2 | 28750.0 | 32622.5 | 1.000 | 1.000 | 31483.5 | 127966.7 | 24.6 | B31.3 |
| 2530 | 14471.9 | 52770.7 | -5.2 | 28750.0 | 65850.8 | 1.000 | 1.000 | 67242.6 | 127966.7 | 52.5 | B31.3 |
| | | | | | | | | | | | |
| 2530 | 14471.9 | 52770.7 | 5.2 | 28750.0 | 67242.6 | 1.000 | 1.000 | 67242.6 | 127966.7 | 52.5 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 2560 | 14823.9 | 9699.8 | 104.5 | 28750.0 | 32553.5 | 2.118 | 1.765 | 22099.7 | 127966.7 | 17.3 | B31.3 |
| | | | | | | | | | | | |
| 2560 | 14823.9 | 4580.6 | -104.5 | 28750.0 | 32552.8 | 1.000 | 1.000 | 19405.6 | 127966.7 | 15.2 | B31.3 |
| 2561 | 14914.2 | 2957.0 | 104.5 | 28750.0 | 32552.8 | 1.000 | 1.000 | 17872.4 | 127966.7 | 14.0 | B31.3 |
| | | | | | | | | | | | |
| 2561 | 14914.2 | 2957.0 | -104.5 | 28750.0 | 32552.7 | 1.000 | 1.000 | 17872.4 | 127966.7 | 14.0 | B31.3 |
| 2610 | 14471.9 | 17095.0 | -0.0 | 28750.0 | 32699.3 | 2.118 | 1.765 | 27293.1 | 127966.7 | 21.3 | B31.3 |
| | | | | | | | | | | | |
| 2610 | 14471.9 | 8073.6 | 0.0 | 28750.0 | 32552.1 | 1.000 | 1.000 | 22545.5 | 127966.7 | 17.6 | B31.3 |
| 2660 | 14471.9 | 78871.4 | -0.0 | 28750.0 | 91951.5 | 1.000 | 1.000 | 93343.3 | 127966.7 | 72.9 | B31.3 |
| | | | | | | | | | | | |
| 2660 | 14471.9 | 78871.4 | 0.0 | 28750.0 | 93343.3 | 1.000 | 1.000 | 93343.3 | 127966.7 | 72.9 | B31.3 |
| 2670 | 14471.9 | 16660.1 | -0.0 | 28750.0 | 32552.1 | 1.000 | 1.000 | 31132.0 | 127966.7 | 24.3 | B31.3 |
| | | | | | | | | | | | |
| 2670 | 13727.3 | 16660.1 | 0.0 | 28750.0 | 32552.1 | 1.000 | 1.000 | 30387.4 | 127966.7 | 23.7 | B31.3 |
| 2710 | 13727.3 | 75916.7 | -0.0 | 28750.0 | 89741.5 | 1.000 | 1.000 | 89644.0 | 127966.7 | 70.1 | B31.3 |
| | | | | | | | | | | | |
| 2710 | 13727.3 | 75916.7 | 0.0 | 28750.0 | 89644.0 | 1.000 | 1.000 | 89644.0 | 127966.7 | 70.1 | B31.3 |
| 2760 | 13727.3 | 54557.5 | -0.0 | 28750.0 | 68382.3 | 1.000 | 1.000 | 68284.8 | 127966.7 | 53.4 | B31.3 |
| | | | | | | | | | | | |
| 2760 | 13727.3 | 54557.5 | 0.0 | 28750.0 | 68284.8 | 1.000 | 1.000 | 68284.8 | 127966.7 | 53.4 | B31.3 |
| 2810 | 13727.3 | 104402.4 | -0.0 | 28750.0 | 118227.2 | 1.000 | 1.000 | 118129.7 | 127966.7 | 92.3 | B31.3 |
| | | | | | | | | | | | |
| 2810 | 13727.3 | 104402.4 | 0.0 | 28750.0 | 118129.7 | 1.000 | 1.000 | 118129.7 | 127966.7 | 92.3 | B31.3 |
| 2818 | 13727.3 | 56347.8 | -0.0 | 28750.0 | 70172.6 | 1.000 | 1.000 | 70075.0 | 127966.7 | 54.8 | B31.3 |
| | | | | | | | | | | | |
| 2818 | 13727.3 | 119321.7 | 0.0 | 28750.0 | 133049.0 | 2.118 | 1.765 | 103218.6 | 127966.7 | 80.7 | B31.3 |
| 2819 | 11862.1 | 93434.1 | -2.5 | 28750.0 | 109124.1 | 2.118 | 1.765 | 81937.6 | 127966.7 | 64.0 | B31.3 |
| | | | | | | | | | | | |
| 2819 | 11862.1 | 93434.1 | 2.5 | 28750.0 | 105296.2 | 2.118 | 1.765 | 81937.6 | 127966.7 | 64.0 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 2820 | 11160.7 | 83253.2 | -3.4 | 28750.0 | 99644.6 | 2.118 | 1.765 | 73600.6 | 127966.7 | 57.5 | B31.3 |
| | | | | | | | | | | | |
| 2820 | 11160.7 | 39315.0 | 3.4 | 28750.0 | 55061.2 | 1.000 | 1.000 | 50475.7 | 127966.7 | 39.4 | B31.3 |
| 2830 | 13727.3 | 71352.1 | -3.3 | 28750.0 | 85177.0 | 2.118 | 1.765 | 67241.4 | 127966.7 | 52.5 | B31.3 |
| | | | | | | | | | | | |
| 2830 | 13727.3 | 33694.9 | 3.3 | 28750.0 | 47422.2 | 1.000 | 1.000 | 47422.2 | 127966.7 | 37.1 | B31.3 |
| 2840 | 14974.8 | 88521.5 | 1.8 | 28750.0 | 101098.8 | 2.118 | 1.765 | 81365.9 | 127966.7 | 63.6 | B31.3 |
| | | | | | | | | | | | |
| 2840 | 14974.8 | 41802.9 | -1.8 | 28750.0 | 56777.7 | 1.000 | 1.000 | 56777.7 | 127966.7 | 44.4 | B31.3 |
| 2850 | 13727.3 | 103755.8 | -0.0 | 28750.0 | 117580.6 | 2.118 | 1.765 | 91544.1 | 127966.7 | 71.5 | B31.3 |
| | | | | | | | | | | | |
| 2850 | 13727.3 | 48997.0 | 0.0 | 28750.0 | 62724.3 | 1.000 | 1.000 | 62724.3 | 127966.7 | 49.0 | B31.3 |
| 2900 | 13727.3 | 43166.0 | -0.0 | 28750.0 | 56990.8 | 1.000 | 1.000 | 56893.2 | 127966.7 | 44.5 | B31.3 |
| | | | | | | | | | | | |
| 2900 | 13727.3 | 43166.0 | 0.0 | 28750.0 | 56893.2 | 1.000 | 1.000 | 56893.2 | 127966.7 | 44.5 | B31.3 |
| 2910 | 13727.3 | 101191.6 | -0.0 | 28750.0 | 115016.5 | 1.000 | 1.000 | 114918.9 | 127966.7 | 89.8 | B31.3 |
| | | | | | | | | | | | |
| 2910 | 13727.3 | 101191.6 | 0.0 | 28750.0 | 114918.9 | 1.000 | 1.000 | 114918.9 | 127966.7 | 89.8 | B31.3 |
| 2960 | 13727.3 | 40662.8 | 0.0 | 28750.0 | 54487.6 | 1.000 | 1.000 | 54390.0 | 127966.7 | 42.5 | B31.3 |
| | | | | | | | | | | | |
| 2960 | 13727.3 | 40662.8 | -0.0 | 28750.0 | 54390.0 | 1.000 | 1.000 | 54390.0 | 127966.7 | 42.5 | B31.3 |
| 3010 | 13727.3 | 89709.8 | 0.0 | 28750.0 | 103534.6 | 1.000 | 1.000 | 103437.1 | 127966.7 | 80.8 | B31.3 |
| | | | | | | | | | | | |
| 3010 | 13776.0 | 89709.8 | 0.0 | 28750.0 | 103485.8 | 1.000 | 1.000 | 103485.8 | 127966.7 | 80.9 | B31.3 |
| 3060 | 13776.0 | 47753.3 | 0.0 | 28750.0 | 61529.4 | 1.000 | 1.000 | 61529.4 | 127966.7 | 48.1 | B31.3 |
| | | | | | | | | | | | |
| 3060 | 13776.0 | 47753.3 | 0.0 | 28750.0 | 61529.4 | 1.000 | 1.000 | 61529.4 | 127966.7 | 48.1 | B31.3 |
| 3110 | 13776.0 | 92213.9 | -0.0 | 28750.0 | 105989.9 | 1.000 | 1.000 | 105989.9 | 127966.7 | 82.8 | B31.3 |
| | | | | | | | | | | | |
| 3110 | 13776.0 | 92213.9 | 0.0 | 28750.0 | 105989.9 | 1.000 | 1.000 | 105989.9 | 127966.7 | 82.8 | B31.3 |

| Node | Axial Stress KPa | Bending Stress KPa | Torsion Stress KPa | Hoop Stress KPa | Max Stress Intensity KPa | SIF In Plane | SIF Out Plane | Code Stress KPa | Allowable Stress KPa | Ratio % | Piping Code |
|------|------------------|--------------------|--------------------|-----------------|--------------------------|--------------|---------------|-----------------|----------------------|---------|-------------|
| 3160 | 13776.0 | 0.0 | -0.0 | 28750.0 | 32552.1 | 1.000 | 1.000 | 13776.0 | 127966.7 | 10.8 | B31.3 |
| | | | | | | | | | | | |
| 1760 | 15504.6 | 17238.9 | 0.0 | 32222.2 | 36018.9 | 2.040 | 2.387 | 28433.7 | 127966.7 | 22.2 | B31.3 |
| 3210 | 15504.6 | 20238.0 | -0.0 | 32222.2 | 36795.2 | 1.000 | 1.000 | 35742.5 | 127966.7 | 27.9 | B31.3 |
| | | | | | | | | | | | |
| 3210 | 15504.6 | 20238.0 | 0.0 | 32222.2 | 36795.2 | 1.000 | 1.000 | 35742.5 | 127966.7 | 27.9 | B31.3 |
| 3260 | 15504.6 | 37266.9 | -0.0 | 32222.2 | 52781.3 | 1.000 | 1.000 | 52771.5 | 127966.7 | 41.2 | B31.3 |
| | | | | | | | | | | | |
| 3260 | 15504.6 | 37266.9 | 0.0 | 32222.2 | 52771.5 | 1.000 | 1.000 | 52771.5 | 127966.7 | 41.2 | B31.3 |
| 3310 | 15504.6 | 25521.1 | -0.0 | 32222.2 | 41697.9 | 1.000 | 1.000 | 41025.6 | 127966.7 | 32.1 | B31.3 |
| | | | | | | | | | | | |
| 3310 | 15504.6 | 25521.1 | 0.0 | 32222.2 | 41697.9 | 1.000 | 1.000 | 41025.6 | 127966.7 | 32.1 | B31.3 |
| 3360 | 15504.6 | 39722.6 | -0.0 | 32222.2 | 55236.9 | 1.000 | 1.000 | 55227.2 | 127966.7 | 43.2 | B31.3 |
| | | | | | | | | | | | |
| 3360 | 15509.5 | 39722.6 | 0.0 | 32222.2 | 55232.1 | 1.000 | 1.000 | 55232.1 | 127966.7 | 43.2 | B31.3 |
| 3410 | 15509.5 | 25884.0 | -0.0 | 32222.2 | 42029.8 | 1.000 | 1.000 | 41393.5 | 127966.7 | 32.3 | B31.3 |
| | | | | | | | | | | | |
| 3410 | 15509.5 | 25884.0 | 0.0 | 32222.2 | 42029.8 | 1.000 | 1.000 | 41393.5 | 127966.7 | 32.3 | B31.3 |
| 3460 | 15509.5 | 42431.7 | -0.0 | 32222.2 | 57941.1 | 1.000 | 1.000 | 57941.1 | 127966.7 | 45.3 | B31.3 |
| | | | | | | | | | | | |
| 3460 | 15509.5 | 42431.7 | 0.0 | 32222.2 | 57941.1 | 1.000 | 1.000 | 57941.1 | 127966.7 | 45.3 | B31.3 |
| 3510 | 15509.5 | 0.0 | -0.0 | 32222.2 | 36018.9 | 1.000 | 1.000 | 15509.5 | 127966.7 | 12.1 | B31.3 |

7.3.2 OPERATIONAL LOAD CASES:

This shall include effects of pressure, temperature, pipe dead weight, insulation weight of the contents and other externally imposed displacement such as nozzle.

Displacements etc. This load case is required to be performed to establish that the operating condition loads on the equipment nozzle and pipe supports are within safe limits.

7.3.2.1 Displacement Loads:

Those loads which act on the pipe due to its displacement. Small and insignificant nodal displacements within the allowable limits are ignored, but if the displacement is more than 10mm, then necessary guide supports or restraints must be provided to check that displacement. A gap of 3mm is allowed during the placement of guide supports. For further Illustration, refer displacement load case report of WI-Discharge given below.

Table 7.3.2.1: Displacement

| Node | DX mm. | DY mm. | DZ mm. | RX deg. | RY deg. | RZ deg. |
|------|---------|---------|---------|---------|---------|---------|
| 10 | 0.600 | -0.000 | -0.000 | 0.0000 | -0.4458 | -0.1317 |
| 58 | -20.420 | 17.368 | -34.584 | 0.5105 | -0.1673 | -0.2247 |
| 59 | -21.477 | 17.303 | -34.468 | 0.5628 | 0.0487 | -0.1779 |
| 60 | -21.154 | 14.697 | -33.225 | 0.6991 | 0.2549 | -0.1322 |
| 110 | -15.226 | -0.000 | -28.935 | 0.8058 | 0.3360 | -0.1165 |
| 120 | -0.000 | -38.597 | -19.404 | 0.9015 | 0.3114 | -0.0815 |
| 160 | 14.999 | -97.990 | -0.000 | 0.3068 | 0.0532 | -0.0103 |
| 210 | 10.782 | -10.037 | 33.157 | -0.7264 | 0.0514 | 0.1218 |
| 211 | 5.000 | -0.000 | 5.000 | -0.4704 | 0.1419 | 0.1231 |
| 220 | 2.916 | 3.816 | -2.163 | -0.3620 | 0.1764 | 0.1160 |
| 260 | -2.432 | 11.043 | -11.486 | -0.2772 | 0.2684 | 0.0995 |
| 310 | -16.261 | -0.000 | -0.000 | -0.3421 | -0.0134 | 0.3348 |
| 360 | -32.431 | -26.589 | -13.645 | -0.3837 | -0.2229 | 0.4533 |
| 410 | -40.075 | -21.528 | -17.612 | -0.1944 | -0.1210 | 0.3657 |
| 460 | -41.306 | -19.555 | -15.232 | -0.1709 | -0.1047 | 0.3491 |
| 470 | -45.193 | -8.900 | -0.000 | -0.1590 | -0.0092 | 0.2425 |
| 480 | -39.665 | -0.000 | 23.148 | 0.1521 | 0.1073 | 0.0801 |
| 490 | -22.244 | -29.624 | 47.851 | 0.0638 | 0.1931 | -0.0931 |
| 518 | -4.666 | -5.947 | 65.773 | -0.6563 | 0.2305 | -0.2188 |
| 519 | -3.123 | -1.838 | 65.147 | -0.9456 | 0.2506 | -0.2355 |
| 520 | -1.453 | 1.159 | 60.563 | -1.1839 | 0.2648 | -0.2731 |
| 530 | 14.319 | 15.498 | 8.950 | -0.3604 | 0.3111 | -0.3646 |
| 540 | 17.849 | 16.636 | 10.435 | 0.7567 | 0.3059 | -0.4204 |
| 550 | -0.666 | 1.485 | -29.324 | 0.6868 | 0.3051 | -0.5084 |
| 560 | 0.000 | -0.000 | -28.849 | 0.6791 | 0.3055 | -0.5117 |

| Node | DX mm. | DY mm. | DZ mm. | RX deg. | RY deg. | RZ deg. |
|------|----------|---------|----------|---------|---------|---------|
| 610 | 40.154 | -32.913 | 0.000 | -0.2697 | 0.2848 | -0.7141 |
| 660 | 62.825 | 9.863 | 19.391 | -0.5416 | 0.2183 | -0.8497 |
| 710 | 63.072 | 10.478 | 19.638 | -0.5383 | 0.2172 | -0.8515 |
| 760 | 63.800 | 23.633 | 27.195 | 0.2544 | 0.1165 | -0.9664 |
| 770 | -0.000 | 9.840 | 0.000 | 0.4950 | 0.0199 | -1.0541 |
| 810 | -66.474 | -7.644 | -33.213 | 0.3939 | -0.1397 | 0.0792 |
| 860 | -56.797 | -0.000 | -26.075 | 0.3684 | -0.1783 | 0.1134 |
| 870 | -26.335 | -12.111 | -0.000 | 0.2879 | -0.1596 | 0.0018 |
| 910 | 0.000 | -0.000 | 13.321 | 0.2183 | -0.0661 | 0.0032 |
| 960 | 23.325 | -0.477 | 17.952 | 0.1267 | 0.0210 | 0.6256 |
| 961 | 21.944 | -0.000 | 18.228 | 0.1257 | 0.0221 | 0.6389 |
| 1010 | -93.333 | 35.718 | 33.243 | 0.0714 | 0.1216 | 0.0242 |
| 1060 | -62.363 | -0.000 | 12.925 | 0.0505 | 0.1582 | -0.4525 |
| 1110 | -30.276 | -45.650 | -10.518 | 0.0289 | 0.1537 | 0.0941 |
| 1160 | -2.000 | -0.000 | -28.212 | 0.0098 | 0.1140 | 0.3132 |
| 1210 | 20.516 | 10.391 | -37.296 | -0.0054 | 0.0583 | -0.0228 |
| 1260 | 37.325 | -0.000 | -39.730 | -0.0168 | 0.0028 | -0.3146 |
| 1310 | 99.790 | -0.000 | 0.000 | -0.0590 | -0.3075 | 0.3672 |
| 1360 | 120.404 | 14.015 | 22.571 | -0.0730 | -0.0332 | -0.0556 |
| 1410 | 134.428 | -0.000 | 22.882 | 0.1637 | 0.0673 | -0.4286 |
| 1460 | 152.260 | -50.862 | -0.000 | 0.4646 | 0.5624 | -0.6906 |
| 1510 | 160.573 | -76.357 | -27.551 | 0.6049 | 0.8801 | -0.6387 |
| 1518 | 161.049 | -77.746 | -29.491 | 0.6129 | 0.8977 | -0.6346 |
| 1519 | 159.984 | -79.286 | -34.677 | 0.6632 | 1.1736 | -0.5538 |
| 1520 | 154.339 | -76.994 | -38.111 | 0.7645 | 1.4233 | -0.5064 |
| 1530 | 17.889 | 3.214 | -63.534 | 0.6982 | 0.2658 | -0.2988 |
| 1532 | 20.268 | -0.000 | -65.628 | 0.6394 | 0.1175 | -0.2968 |
| 1540 | 24.192 | -16.125 | -49.276 | 0.1763 | -1.4858 | -0.0861 |
| 1550 | -149.851 | -13.394 | -17.796 | -0.1631 | -1.3556 | 0.2599 |
| 1560 | -137.255 | -0.000 | 49.152 | -0.1424 | -0.9703 | 0.1159 |
| 1610 | -85.158 | -0.000 | 129.289 | -0.0567 | 0.1801 | -0.0992 |
| 1660 | -52.097 | -22.623 | 71.037 | -0.0024 | 0.5404 | 0.0833 |
| 1710 | -26.651 | -0.000 | 1.555 | 0.0395 | 0.6222 | 0.0761 |
| 1711 | 0.000 | -8.532 | -70.470 | 0.0833 | 0.5255 | -0.0083 |
| 1720 | 22.888 | -0.000 | -114.593 | 0.1209 | 0.2941 | 0.0531 |
| 1760 | 29.311 | 0.138 | -121.949 | 0.1314 | 0.2045 | -0.0337 |
| 1761 | -5.000 | -0.000 | -140.995 | -0.2795 | 0.6232 | -0.2770 |
| 1768 | -122.775 | -71.372 | -167.282 | -0.6819 | 1.3141 | -0.6128 |
| 1769 | -129.677 | -73.246 | -165.542 | -0.6432 | 1.4943 | -0.6442 |
| 1770 | -133.665 | -71.308 | -158.635 | -0.6155 | 1.6550 | -0.7154 |
| 1780 | -162.168 | 6.622 | 8.196 | -0.6047 | 0.4761 | -0.5344 |
| 1781 | -166.632 | -0.000 | 5.816 | -0.6158 | 0.3419 | -0.4623 |
| 1790 | -164.178 | -32.948 | -0.450 | -0.4851 | -1.0946 | 0.0774 |
| 1800 | -132.222 | 0.631 | 150.480 | -0.2910 | -1.1965 | 0.5218 |

| Node | DX mm. | DY mm. | DZ mm. | RX deg. | RY deg. | RZ deg. |
|------|----------|----------|----------|---------|---------|---------|
| 1810 | -129.622 | -0.000 | 150.004 | -0.2903 | -1.1864 | 0.5218 |
| 1860 | -32.305 | -16.184 | 128.003 | 0.0375 | -0.7574 | 0.5218 |
| 1910 | 32.248 | -0.000 | 102.192 | -0.0031 | -0.3521 | 0.5218 |
| 1960 | 45.607 | -0.000 | 45.908 | 0.0972 | 0.1645 | 0.5218 |
| 2010 | 27.082 | -1.399 | 25.811 | -0.0182 | 0.2270 | 0.5218 |
| 2060 | 0.000 | -0.000 | -0.000 | -0.0984 | 0.2132 | 0.5218 |
| 2110 | -21.402 | -18.408 | -25.851 | -0.0188 | 0.1499 | 0.5218 |
| 2160 | -36.535 | -0.000 | -53.610 | 0.1031 | 0.0898 | 0.5218 |
| 2210 | -46.363 | -0.000 | -98.536 | -0.0986 | 0.0094 | 0.5218 |
| 2260 | -45.233 | -17.419 | -124.387 | -0.0081 | -0.0273 | 0.5218 |
| 2310 | -40.174 | -0.000 | -150.237 | 0.1312 | -0.0571 | 0.5218 |
| 2360 | -26.065 | -0.000 | -191.349 | -0.1849 | -0.0900 | 0.5218 |
| 2410 | -12.871 | -29.499 | -221.015 | 0.0163 | -0.1029 | 0.5218 |
| 2411 | -0.000 | -0.000 | -247.721 | 0.2647 | -0.1066 | 0.5218 |
| 2460 | 8.884 | 14.223 | -265.942 | 0.1401 | -0.1066 | 0.5218 |
| 2510 | 103.439 | -0.000 | 11.441 | -0.5253 | 0.6328 | -0.1863 |
| 2520 | 61.092 | -37.299 | 0.000 | -0.7774 | 0.9146 | -0.3207 |
| 2530 | 2.000 | -78.426 | -15.233 | -0.2906 | 0.6551 | -0.4998 |
| 2560 | -25.989 | -47.628 | -32.839 | 1.0382 | 0.0128 | -0.8334 |
| 2561 | -18.657 | -45.719 | -23.613 | 1.0685 | -0.0097 | -0.8451 |
| 2610 | -4.878 | -36.914 | -7.961 | 0.9742 | -0.0938 | -0.8817 |
| 2660 | -0.000 | -0.000 | -17.736 | 0.5832 | -0.1006 | -0.8817 |
| 2670 | 4.164 | 16.711 | -44.394 | -0.0007 | 0.0163 | -0.8817 |
| 2710 | 0.000 | -0.000 | -70.541 | -0.5795 | 0.0377 | -0.8817 |
| 2760 | -3.660 | -105.764 | -104.306 | -0.0606 | 0.0116 | -0.8817 |
| 2810 | -4.220 | -0.000 | -136.166 | 1.0543 | -0.0022 | -0.8817 |
| 2818 | -4.185 | 14.383 | -139.213 | 1.0296 | -0.0029 | -0.8817 |
| 2819 | -2.820 | 18.620 | -138.384 | 1.0931 | -0.0040 | -0.8820 |
| 2820 | 0.453 | 21.144 | -134.515 | 1.1705 | -0.0044 | -0.8822 |
| 2830 | 78.965 | 39.162 | -55.127 | -0.6520 | -0.0105 | -0.8795 |
| 2840 | 74.854 | -5.286 | -55.940 | -1.7689 | -0.0133 | -0.8756 |
| 2850 | -2.879 | -30.345 | 102.687 | -0.7792 | -0.0167 | -0.8733 |
| 2900 | -1.814 | -49.175 | 89.107 | 0.1338 | -0.0172 | -0.8733 |
| 2910 | -0.000 | -0.000 | 63.720 | 0.1562 | -0.0129 | -0.8733 |
| 2960 | 1.195 | -30.847 | 33.764 | -0.0817 | -0.0049 | -0.8733 |
| 3010 | 1.417 | -0.000 | -0.000 | -0.0564 | 0.0016 | -0.8733 |
| 3060 | 0.848 | -43.427 | -33.826 | 0.0636 | 0.0053 | -0.8733 |
| 3110 | 0.000 | -0.000 | -64.347 | 0.0347 | 0.0064 | -0.8733 |
| 3160 | -0.771 | -48.888 | -90.538 | -0.5544 | 0.0064 | -0.8733 |
| 3210 | 25.730 | -7.076 | -101.936 | -0.0285 | -0.2205 | -0.0337 |
| 3260 | 0.000 | -0.000 | -81.923 | -0.0115 | -0.2785 | -0.0337 |
| 3310 | -31.158 | -0.000 | -39.057 | -0.0379 | -0.0532 | -0.0337 |
| 3360 | -27.946 | -0.000 | 0.000 | 0.0923 | 0.0771 | -0.0337 |
| 3410 | -18.947 | -14.365 | 20.047 | 0.0905 | 0.1160 | -0.0337 |

| Node | DX mm. | DY mm. | DZ mm. | RX deg. | RY deg. | RZ deg. |
|------|--------|--------|--------|---------|---------|---------|
| 3460 | -0.000 | -0.000 | 51.540 | -0.0787 | 0.1392 | -0.0337 |
| 3510 | 12.768 | -4.262 | 71.586 | 0.0873 | 0.1392 | -0.0337 |

7.3.2.2 RESTRAIN REPORT

Table 7.3.2.2: Restrain report

| Node | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. | |
|------|-------|--------|-------|---------|---------|---------|----------|
| 10 | 0 | 0 | 0 | 0 | 0 | 0 | Flex X |
| 10 | 0 | 0 | 0 | 12946 | 0 | 0 | Rigid RX |
| 10 | 0 | 0 | 0 | 0 | 0 | 0 | Rigid Z |
| 10 | 0 | 0 | 0 | 0 | 0 | -293 | Flex RZ |
| 10 | 0 | -3455 | 0 | 0 | 0 | 0 | Rigid Y |
| 10 | 0 | 0 | 0 | 0 | -0 | 0 | Flex RY |
| 110 | 0 | -16827 | 0 | 0 | 0 | 0 | Rigid +Y |
| 211 | 0 | -16294 | 0 | 0 | 0 | 0 | Rigid +Y |
| 310 | 0 | -16725 | 0 | 0 | 0 | 0 | Rigid +Y |
| 510 | 0 | -15777 | 0 | 0 | 0 | 0 | Rigid +Y |
| 560 | 0 | -17347 | 0 | 0 | 0 | 0 | Rigid +Y |
| 660 | 0 | -15567 | 0 | 0 | 0 | 0 | Rigid +Y |
| 860 | 0 | -17083 | 0 | 0 | 0 | 0 | Rigid +Y |
| 910 | 0 | -16093 | 0 | 0 | 0 | 0 | Rigid +Y |
| 961 | 0 | -15109 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1060 | 0 | -17814 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1160 | 0 | -15285 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1260 | 0 | -16858 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1310 | 0 | -14962 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1410 | 0 | -14966 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1510 | 0 | -17128 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1610 | 0 | -16977 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1710 | 0 | -15546 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1720 | 0 | -21654 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1810 | 0 | -15966 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1910 | 0 | -16770 | 0 | 0 | 0 | 0 | Rigid +Y |
| 1960 | 0 | -16651 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2060 | 0 | -16538 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2160 | 0 | -16120 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2210 | 0 | -15457 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2310 | 0 | -14169 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2360 | 0 | -16433 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2411 | 0 | -14430 | 0 | 0 | 0 | 0 | Rigid +Y |

| Node | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. | |
|------|-------|--------|-------|------------|------------|---------|----------|
| 2510 | 0 | -12499 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2660 | 0 | -14306 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2710 | 0 | -13525 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2810 | 0 | -15120 | 0 | 0 | 0 | 0 | Rigid +Y |
| 2910 | 0 | -13344 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3010 | 0 | -13650 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3110 | 0 | -13071 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3260 | 0 | -14079 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3310 | 0 | -12154 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3360 | 0 | -14940 | 0 | 0 | 0 | 0 | Rigid +Y |
| 3460 | 0 | -14709 | 0 | 0 | 0 | 0 | Rigid +Y |

7.3.3 Expansion Load

These are loads due to displacement of piping. E.g. Thermal expansion, seismic anchor movements and building settlement.

LOAD CASE DEFINITION KEY

CASE 3 (EXP) L3=L1-L2

Piping Code: B31.3 = B31.3 -2010

*** CODE COMPLIANCE EVALUATION PASSED ***

Highest Stresses: (KPa)

Ratio (%): 85.4 @Node 1540 LOADCASE: 3 (EXP) L3=L1-L2

Code Stress: 228546.7 Allowable Stresses: 267761.2

Axial Stress: 2945.8 @Node 480 LOADCASE: 3 (EXP) L3=L1-L2

Bending Stress: 238499.9 @Node 1530 LOADCASE: 3 (EXP) L3=L1-L2

Torsion Stress: 9199.7 @Node 360 LOADCASE: 3 (EXP) L3=L1-L2

Hoop Stress: 0.0 @Node 58 LOADCASE: 3 (EXP) L3=L1-L2

Max Stress Intensity: 240096.8 @Node 1530 LOADCASE: 3 (EXP) L3=L1-L2

Table 7.3.3: Code Evaluation

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 3(EXP) | 10 | 5190.4 | 297403.8 | 58 | 69015.8 | 284746.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 58 | 155577.4 | 272685.6 | 59 | 157175.8 | 264909.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 59 | 157175.8 | 264909.5 | 60 | 144891.6 | 258031.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 60 | 64317.5 | 277335.6 | 110 | 35294.7 | 267791.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 110 | 35294.7 | 267791.5 | 120 | 30105.5 | 303023.6 | B31.3 |
| | | | | | | | |
| 3(EXP) | 120 | 30105.5 | 303023.6 | 160 | 18456.2 | 239813.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 160 | 18456.2 | 239813.1 | 210 | 11167.8 | 261106.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 210 | 7226.0 | 282999.1 | 211 | 39008.9 | 293460.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 211 | 39008.9 | 295354.1 | 220 | 22173.8 | 299306.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 220 | 22173.8 | 299306.8 | 260 | 14723.8 | 306552.0 | B31.3 |
| | | | | | | | |
| 3(EXP) | 260 | 14272.5 | 309451.6 | 310 | 64826.3 | 247670.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 310 | 64826.3 | 247670.8 | 360 | 26567.7 | 304459.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 360 | 20468.3 | 308096.2 | 410 | 49237.0 | 304541.2 | B31.3 |
| | | | | | | | |
| 3(EXP) | 410 | 24751.0 | 308718.6 | 460 | 24122.3 | 310409.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 460 | 24122.3 | 310409.1 | 470 | 20142.3 | 301411.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 470 | 20142.3 | 301411.7 | 480 | 14332.6 | 256691.2 | B31.3 |
| | | | | | | | |
| 3(EXP) | 480 | 14332.6 | 256691.2 | 490 | 27766.6 | 285253.0 | B31.3 |
| | | | | | | | |
| 3(EXP) | 490 | 27766.6 | 285253.0 | 518 | 51246.1 | 300056.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 518 | 114779.2 | 288510.8 | 519 | 105731.0 | 292958.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 519 | 105731.0 | 292958.4 | 520 | 77012.2 | 295226.6 | B31.3 |
| | | | | | | | |
| 3(EXP) | 520 | 34367.8 | 303676.3 | 530 | 219574.0 | 314037.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 530 | 97422.8 | 315020.2 | 540 | 163770.4 | 277974.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 540 | 72649.9 | 294377.5 | 550 | 140942.6 | 261069.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 550 | 62765.0 | 283851.3 | 560 | 63407.6 | 279612.2 | B31.3 |


| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| | | | | | | | |
| 3(EXP) | 560 | 63407.6 | 279612.2 | 610 | 32334.1 | 291527.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 610 | 32334.1 | 291472.3 | 660 | 14442.7 | 284710.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 660 | 14442.7 | 284710.8 | 710 | 12769.3 | 285851.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 710 | 12769.3 | 285851.8 | 760 | 153144.2 | 311515.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 760 | 68513.3 | 313085.2 | 770 | 17050.3 | 313912.0 | B31.3 |
| | | | | | | | |
| 3(EXP) | 770 | 17050.3 | 313912.0 | 810 | 187010.0 | 311766.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 810 | 83108.2 | 313858.5 | 860 | 22300.9 | 267604.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 860 | 22300.9 | 267604.5 | 870 | 14516.8 | 280218.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 870 | 14516.8 | 280218.7 | 910 | 7420.5 | 269230.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 910 | 7420.5 | 269177.2 | 960 | 105980.1 | 313931.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 960 | 47128.3 | 315007.3 | 961 | 45659.4 | 315015.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 961 | 45659.4 | 317236.1 | 1010 | 129111.5 | 314102.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1010 | 57264.9 | 315206.7 | 1060 | 26458.5 | 259585.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1060 | 26458.5 | 259585.8 | 1110 | 8462.8 | 272229.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1110 | 8462.8 | 272229.3 | 1160 | 9705.9 | 270566.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1160 | 9705.9 | 270566.7 | 1210 | 7985.0 | 305181.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1210 | 7985.0 | 305181.3 | 1260 | 9031.0 | 261178.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1260 | 9031.0 | 261178.8 | 1310 | 15110.0 | 268098.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1310 | 15110.0 | 268098.8 | 1360 | 167587.7 | 254898.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1360 | 41123.2 | 253976.2 | 1410 | 39057.5 | 245199.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1410 | 39057.5 | 245199.4 | 1460 | 63878.8 | 302760.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1460 | 63878.8 | 302760.3 | 1510 | 60332.8 | 295750.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1510 | 60332.8 | 295750.7 | 1518 | 60129.9 | 295639.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1518 | 135637.8 | 290663.9 | 1519 | 127872.2 | 280663.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1519 | 127872.2 | 280663.9 | 1520 | 111054.2 | 283981.0 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 3(EXP) | 1520 | 49232.0 | 292537.2 | 1530 | 238501.0 | 291470.1 | B31.3 |
| 3(EXP) | 1530 | 105726.6 | 293228.6 | 1532 | 106739.3 | 294293.6 | B31.3 |
| 3(EXP) | 1532 | 106739.3 | 294293.6 | 1540 | 228546.7 | 267761.2 | B31.3 |
| 3(EXP) | 1540 | 101312.6 | 280653.3 | 1550 | 118261.0 | 299162.7 | B31.3 |
| 3(EXP) | 1550 | 52423.7 | 304382.7 | 1560 | 47062.0 | 260569.6 | B31.3 |
| 3(EXP) | 1560 | 47062.0 | 260569.6 | 1610 | 24877.7 | 263324.1 | B31.3 |
| 3(EXP) | 1610 | 24877.7 | 263324.1 | 1660 | 10800.4 | 283272.5 | B31.3 |
| 3(EXP) | 1660 | 10800.4 | 283272.5 | 1710 | 53.2 | 259446.0 | B31.3 |
| 3(EXP) | 1710 | 53.2 | 259446.0 | 1711 | 11382.2 | 295260.8 | B31.3 |
| 3(EXP) | 1711 | 11382.2 | 295240.3 | 1720 | 21108.9 | 285983.0 | B31.3 |
| 3(EXP) | 1720 | 21108.9 | 285983.0 | 1760 | 48633.7 | 286499.0 | B31.3 |
| 3(EXP) | 1760 | 54551.4 | 302695.0 | 1761 | 48527.0 | 233905.2 | B31.3 |
| 3(EXP) | 1761 | 48527.0 | 233905.2 | 1768 | 41378.9 | 305893.3 | B31.3 |
| 3(EXP) | 1768 | 93345.5 | 304335.3 | 1769 | 87528.3 | 293732.2 | B31.3 |
| 3(EXP) | 1769 | 87528.3 | 293732.2 | 1770 | 74723.5 | 292286.9 | B31.3 |
| 3(EXP) | 1770 | 33124.0 | 299241.3 | 1780 | 216001.0 | 288495.6 | B31.3 |
| 3(EXP) | 1780 | 95750.6 | 288780.5 | 1781 | 96397.9 | 282362.7 | B31.3 |
| 3(EXP) | 1781 | 96397.9 | 282362.7 | 1790 | 206725.6 | 258068.2 | B31.3 |
| 3(EXP) | 1790 | 91638.9 | 274800.6 | 1800 | 82245.7 | 312115.7 | B31.3 |
| 3(EXP) | 1800 | 36458.5 | 313483.3 | 1810 | 36329.0 | 315605.3 | B31.3 |
| 3(EXP) | 1810 | 36329.0 | 315605.3 | 1860 | 30346.3 | 284282.4 | B31.3 |
| 3(EXP) | 1860 | 30346.3 | 284282.4 | 1910 | 23327.7 | 255394.9 | B31.3 |
| 3(EXP) | 1910 | 23327.7 | 255394.9 | 1960 | 8022.6 | 272476.1 | B31.3 |
| 3(EXP) | 1960 | 8022.6 | 272476.1 | 2010 | 2557.8 | 306333.4 | B31.3 |
| 3(EXP) | 2010 | 2557.8 | 306333.4 | 2060 | 4460.8 | 272214.8 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| | | | | | | | |
| 3(EXP) | 2060 | 4460.8 | 272214.8 | 2110 | 3995.3 | 285220.0 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2110 | 3995.3 | 285220.0 | 2160 | 3495.4 | 273112.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2160 | 3495.4 | 273112.9 | 2210 | 2686.4 | 274144.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2210 | 2686.4 | 274144.1 | 2260 | 2220.9 | 285704.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2260 | 2220.9 | 285704.7 | 2310 | 1755.4 | 280601.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2310 | 1755.4 | 280601.3 | 2360 | 1015.1 | 267276.4 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2360 | 1015.1 | 267276.4 | 2410 | 480.9 | 275082.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2410 | 480.9 | 275082.1 | 2411 | 0.0 | 281763.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2411 | 0.0 | 281763.8 | 2460 | 0.0 | 316817.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 1360 | 191546.2 | 257006.0 | 2510 | 66736.1 | 266761.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2510 | 66736.1 | 266761.9 | 2520 | 18143.8 | 300843.8 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2520 | 18143.8 | 300843.8 | 2530 | 59197.5 | 265084.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2530 | 59197.5 | 265084.7 | 2560 | 75253.0 | 310227.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2560 | 37689.3 | 312921.7 | 2561 | 18096.2 | 314454.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2561 | 18096.2 | 314454.9 | 2610 | 63100.4 | 305034.1 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2610 | 30360.3 | 309781.8 | 2660 | 16381.7 | 238984.0 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2660 | 16381.7 | 238984.0 | 2670 | 15738.3 | 301195.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2670 | 15738.3 | 301939.9 | 2710 | 16583.8 | 242683.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2710 | 16583.8 | 242683.3 | 2760 | 28572.7 | 264042.5 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2760 | 28572.7 | 264042.5 | 2810 | 71116.4 | 214197.6 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2810 | 71116.4 | 214197.6 | 2818 | 67087.6 | 262252.3 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2818 | 142063.8 | 229108.7 | 2819 | 134280.3 | 250389.6 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2819 | 134280.3 | 250389.6 | 2820 | 120014.2 | 258726.7 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2820 | 56675.4 | 281851.6 | 2830 | 203632.1 | 265085.9 | B31.3 |
| | | | | | | | |
| 3(EXP) | 2830 | 96162.5 | 284905.1 | 2840 | 210375.5 | 250961.3 | B31.3 |

| Load Case | From Node | Code Stress KPa | Allowable Stress KPa | To Node | Code Stress KPa | Allowable Stress KPa | Piping Code |
|-----------|-----------|-----------------|----------------------|---------|-----------------|----------------------|-------------|
| 3(EXP) | 2840 | 99346.7 | 275549.6 | 2850 | 106872.3 | 240783.2 | B31.3 |
| 3(EXP) | 2850 | 50468.8 | 269603.0 | 2900 | 32510.2 | 275434.1 | B31.3 |
| 3(EXP) | 2900 | 32510.2 | 275434.1 | 2910 | 1133.2 | 217408.4 | B31.3 |
| 3(EXP) | 2910 | 1133.2 | 217408.4 | 2960 | 535.1 | 277937.3 | B31.3 |
| 3(EXP) | 2960 | 535.1 | 277937.3 | 3010 | 332.1 | 228890.2 | B31.3 |
| 3(EXP) | 3010 | 332.1 | 228841.5 | 3060 | 157.5 | 270797.9 | B31.3 |
| 3(EXP) | 3060 | 157.5 | 270797.9 | 3110 | 0.0 | 226337.4 | B31.3 |
| 3(EXP) | 3110 | 0.0 | 226337.4 | 3160 | 0.0 | 318551.2 | B31.3 |
| 3(EXP) | 1760 | 103185.1 | 303893.5 | 3210 | 20019.7 | 296584.7 | B31.3 |
| 3(EXP) | 3210 | 20019.7 | 296584.7 | 3260 | 10537.6 | 279555.8 | B31.3 |
| 3(EXP) | 3260 | 10537.6 | 279555.8 | 3310 | 7150.9 | 291301.7 | B31.3 |
| 3(EXP) | 3310 | 7150.9 | 291301.7 | 3360 | 4065.1 | 277100.1 | B31.3 |
| 3(EXP) | 3360 | 4065.1 | 277095.2 | 3410 | 2483.9 | 290933.8 | B31.3 |
| 3(EXP) | 3410 | 2483.9 | 290933.8 | 3460 | 0.0 | 274386.1 | B31.3 |
| 3(EXP) | 3460 | 0.0 | 274386.1 | 3510 | 0.0 | 316817.8 | B31.3 |

7.3.3.1 Expansion Loop



$$W = \frac{6.2225 * \sqrt{\Delta} D}{5}$$

L=W*2

W-Width of the loop

L-Length of the loop

D-Outside diameter of the pipe

$\sqrt{\Delta}$ -Deflection of pipe




Fig 7.3.3.1:Expansion Loop

LOAD CASE DEFINITION KEY

CASE 1 (OPE) W+T1+P1

CASE 2 (SUS) W+P1

CASE 3 (EXP) L3=L1-L2

Table 7.3.3.1 Loop Determination

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-----------|---|----------|----------|----------|----------|---------|
| 10 | | Flex X; Rigid RX; Rigid Z; Flex RZ; Rigid Y; Flex RY | | | | | |
| | 1(OPE) | 8022 | -3213 | -3625 | 12707 | -1043 | -308 |
| | 2(SUS) | -2261 | -3455 | 1663 | 11854 | 828 | -258 |
| | 3(EXP) | 10283 | 242 | -5288 | 853 | -1871 | -50 |
| | MAX | 10283/L3 | -3455/L2 | -5288/L3 | 12707/L1 | -1871/L3 | -308/L1 |
| 110 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -16950 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -16422 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -528 | 0 | 0 | 0 | 0 |
| | MAX | | - | 16950/L1 | | | |
| 120 | | Rigid GUI | | | | | |
| | 1(OPE) | -9110 | 0 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 2101 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -11211 | 0 | 0 | 0 | 0 | 0 |
| | MAX | - | 11211/L3 | | | | |
| 160 | | Rigid +Z | | | | | |
| | 1(OPE) | 0 | 0 | -1071 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | -1071 | 0 | 0 | 0 |
| | MAX | | | -1071/L1 | | | |
| 211 | | Rigid +Y; Rigid GUI w/gap; Rigid GUI w/gap | | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|------------------------|---------|--------|----------|----------|---------|---------|
| | 1(OPE) | 1255 | -13161 | 13167 | 0 | 0 | 0 |
| | 2(SUS) | 40 | -13086 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 1214 | -75 | 13167 | 0 | 0 | 0 |
| | MAX | 1255/L1 | - | 13161/L1 | 13167/L1 | | |
| | | | | | | | |
| 310 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | 0 | -19420 | -18410 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -19479 | -2134 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 59 | -16277 | 0 | 0 | 0 |
| | MAX | | - | 19479/L2 | 18410/L1 | | |
| | | | | | | | |
| 470 | Rigid +Z | | | | | | |
| | 1(OPE) | 0 | 0 | -10605 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | -10605 | 0 | 0 | 0 |
| | MAX | | | - | 10605/L1 | | |
| | | | | | | | |
| 480 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -19860 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -18111 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -1749 | 0 | 0 | 0 | 0 |
| | MAX | | - | 19860/L1 | | | |
| | | | | | | | |
| 560 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | 122 | -17712 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 143 | -21421 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -21 | 3709 | 0 | 0 | 0 | 0 |
| | MAX | 143/L2 | - | 21421/L2 | | | |
| | | | | | | | |
| 610 | Rigid -Z | | | | | | |
| | 1(OPE) | 0 | 0 | 11898 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 378 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 11520 | 0 | 0 | 0 |
| | MAX | | | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-------------------------|---------|----------|----------|---------|---------|---------|
| | | | | 11898/L1 | | | |
| 660 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | 0 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14571 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 14571 | 0 | 0 | 0 | 0 |
| | MAX | | - | | | | |
| | | | 14571/L2 | | | | |
| 770 | Rigid GUI; Rigid GUI | | | | | | |
| | 1(OPE) | -10727 | 0 | 9235 | 0 | 0 | 0 |
| | 2(SUS) | -478 | 0 | 31 | 0 | 0 | 0 |
| | 3(EXP) | -10249 | 0 | 9204 | 0 | 0 | 0 |
| | MAX | - | | 9235/L1 | | | |
| | | | | | | | |
| 860 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -34632 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -17890 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -16742 | 0 | 0 | 0 | 0 |
| | MAX | | - | 34632/L1 | | | |
| | | | | | | | |
| 870 | Rigid GUI | | | | | | |
| | 1(OPE) | 0 | 0 | -697 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 96 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | -794 | 0 | 0 | 0 |
| | MAX | | | -794/L3 | | | |
| | | | | | | | |
| 910 | Rigid +Y; Rigid -X | | | | | | |
| | 1(OPE) | 5670 | -18631 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 361 | -16081 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 5309 | -2550 | 0 | 0 | 0 | 0 |
| | MAX | 5670/L1 | - | 18631/L1 | | | |
| | | | | | | | |
| 961 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -16147 | 0 | 0 | 0 | 0 |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-----------|--------------------------------|---------------|---------|---------|---------|---------|
| | 2(SUS) | 0 | -15131 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -1015 | 0 | 0 | 0 | 0 |
| | MAX | | - 16147/L1 | | | | |
| | | | | | | | |
| 1060 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -12795 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -17740 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 4945 | 0 | 0 | 0 | 0 |
| | MAX | | - 17740/L2 | | | | |
| | | | | | | | |
| 1160 | | Rigid +Y; Rigid +X w/gap | | | | | |
| | 1(OPE) | -9919 | -16518 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -15307 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -9919 | -1211 | 0 | 0 | 0 | 0 |
| | MAX | -9919/L1 | - 16518/L1 | | | | |
| | | | | | | | |
| 1260 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -16517 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -16824 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 307 | 0 | 0 | 0 | 0 |
| | MAX | | - 16824/L2 | | | | |
| | | | | | | | |
| 1310 | | Rigid +Y; Rigid GUI | | | | | |
| | 1(OPE) | 0 | -13633 | 4990 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14691 | -2171 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 1057 | 7161 | 0 | 0 | 0 |
| | MAX | | - 14691/L2 | 7161/L3 | | | |
| | | | | | | | |
| 1410 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -14719 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -15524 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 805 | 0 | 0 | 0 | 0 |
| | MAX | | - 15524/L2 | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-----------|-------|--------|----------|---------|---------|---------|
| 1460 | Rigid GUI | | | | | | |
| | 1(OPE) | 0 | 0 | -4002 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | -1255 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | -2747 | 0 | 0 | 0 |
| | MAX | | | -4002/L1 | | | |
| 1532 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -13117 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -13076 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -42 | 0 | 0 | 0 | 0 |
| | MAX | | - | 13117/L1 | | | |
| 1560 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -18672 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -18611 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -60 | 0 | 0 | 0 | 0 |
| | MAX | | - | 18672/L1 | | | |
| 1610 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -17496 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -17516 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 20 | 0 | 0 | 0 | 0 |
| | MAX | | - | 17516/L2 | | | |
| 1710 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -18194 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -18190 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -5 | 0 | 0 | 0 | 0 |
| | MAX | | - | 18194/L1 | | | |
| 1711 | Rigid -X | | | | | | |
| | 1(OPE) | 10437 | 0 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 140 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 10297 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | | 10437/L1 | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|------------------------------------|----------|---------------|-------|---------|---------|---------|
| 1720 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -11403 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -11404 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 1 | 0 | 0 | 0 | 0 |
| | MAX | | - 11404/L2 | | | | |
| | | | | | | | |
| 1761 | Rigid GUI w/gap; Rigid +Y | | | | | | |
| | 1(OPE) | -2138 | -18269 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -18270 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -2138 | 1 | 0 | 0 | 0 | 0 |
| | MAX | -2138/L1 | - 18270/L2 | | | | |
| | | | | | | | |
| 1781 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -13427 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -13427 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 13427/L2 | | | | |
| | | | | | | | |
| 1810 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -12478 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -12478 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 12478/L2 | | | | |
| | | | | | | | |
| 1910 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -19081 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -19081 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -0 | 0 | 0 | 0 | 0 |
| | MAX | | - 19081/L1 | | | | |
| | | | | | | | |
| 1960 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -15874 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -15874 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-----------|--|---------------|----------|---------|---------|---------|
| | | | 15874/L2 | | | | |
| | | | | | | | |
| 2060 | | Rigid +Y; Rigid GUI; Rigid +Z | | | | | |
| | 1(OPE) | 436 | -15933 | -8314 | 0 | 0 | 0 |
| | 2(SUS) | -2 | -15933 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 438 | -0 | -8314 | 0 | 0 | 0 |
| | MAX | 438/L3 | - 15933/L1 | -8314/L1 | | | |
| | | | | | | | |
| 2160 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -15741 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -15741 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 15741/L2 | | | | |
| | | | | | | | |
| 2210 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -15581 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -15581 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 15581/L1 | | | | |
| | | | | | | | |
| 2310 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -14139 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14139 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 14139/L1 | | | | |
| | | | | | | | |
| 2360 | | Rigid +Y | | | | | |
| | 1(OPE) | 0 | -16442 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -16442 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 0 | 0 | 0 | 0 |
| | MAX | | - 16442/L1 | | | | |
| | | | | | | | |
| 2411 | | Rigid +Y; Rigid GUI | | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|------------------------|----------|-----------|---------|---------|---------|---------|
| | 1(OPE) | -27 | -14429 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14429 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -27 | 0 | 0 | 0 | 0 | 0 |
| | MAX | -27/L3 | -14429/L1 | | | | |
| | | | | | | | |
| 2510 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -11478 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -8496 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -2982 | 0 | 0 | 0 | 0 |
| | MAX | | -11478/L1 | | | | |
| | | | | | | | |
| 2520 | Rigid -Z | | | | | | |
| | 1(OPE) | 0 | 0 | 5289 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | 5289 | 0 | 0 | 0 |
| | MAX | | | 5289/L1 | | | |
| | | | | | | | |
| 2530 | Rigid GUI w/gap | | | | | | |
| | 1(OPE) | 5247 | 0 | 0 | 0 | 0 | 0 |
| | 2(SUS) | -99 | 0 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 5347 | 0 | 0 | 0 | 0 | 0 |
| | MAX | 5347/L3 | | | | | |
| | | | | | | | |
| 2660 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | -1783 | -13473 | 0 | 0 | 0 | 0 |
| | 2(SUS) | -2 | -14754 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -1781 | 1281 | 0 | 0 | 0 | 0 |
| | MAX | -1783/L1 | -14754/L2 | | | | |
| | | | | | | | |
| 2670 | Rigid -Z | | | | | | |
| | 1(OPE) | 0 | 0 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | 0 | 3593 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 0 | -3593 | 0 | 0 | 0 |
| | MAX | | | 3593/L2 | | | |
| | | | | | | | |
| 2710 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | 168 | -14309 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 4 | -13138 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 165 | -1171 | 0 | 0 | 0 | 0 |
| | MAX | 168/L1 | -14309/L1 | | | | |
| | | | | | | | |
| 2810 | Rigid +Y | | | | | | |
| | 1(OPE) | 0 | -19352 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -21607 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 2255 | 0 | 0 | 0 | 0 |
| | MAX | | -21607/L2 | | | | |
| | | | | | | | |
| 2910 | Rigid +Y; | | | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|------------------------|---------|---------------|----------|---------|---------|---------|
| | Rigid GUI | | | | | | |
| | 1(OPE) | -15 | -16313 | 0 | 0 | 0 | 0 |
| | 2(SUS) | -0 | -15174 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -14 | -1139 | 0 | 0 | 0 | 0 |
| | MAX | -15/L1 | - 16313/L1 | | | | |
| | | | | | | | |
| 3010 | Rigid +Y; Rigid +Z | | | | | | |
| | 1(OPE) | 0 | -14436 | -6845 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14457 | -235 | 0 | 0 | 0 |
| | 3(EXP) | 0 | 21 | -6609 | 0 | 0 | 0 |
| | MAX | | - 14457/L2 | -6845/L1 | | | |
| | | | | | | | |
| 3110 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | 3 | -13371 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -13368 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 3 | -3 | 0 | 0 | 0 | 0 |
| | MAX | 3/L1 | - 13371/L1 | | | | |
| | | | | | | | |
| 3260 | Rigid +Y; Rigid GUI | | | | | | |
| | 1(OPE) | 2479 | -14807 | 0 | 0 | 0 | 0 |
| | 2(SUS) | 55 | -14806 | 0 | 0 | 0 | 0 |
| | 3(EXP) | 2424 | -1 | 0 | 0 | 0 | 0 |
| | MAX | 2479/L1 | - 14807/L1 | | | | |
| | | | | | | | |
| 3360 | Rigid +Y; Rigid -Z | | | | | | |
| | 1(OPE) | 0 | -14944 | 8990 | 0 | 0 | 0 |
| | 2(SUS) | 0 | -14944 | 33 | 0 | 0 | 0 |
| | 3(EXP) | 0 | -0 | 8956 | 0 | 0 | 0 |
| | MAX | | - 14944/L1 | 8990/L1 | | | |
| | | | | | | | |
| 3460 | Rigid +Y; | | | | | | |
| | Rigid | | | | | | |

| Node | Load Case | FX N. | FY N. | FZ N. | MX N.m. | MY N.m. | MZ N.m. |
|------|-----------|---------|--------|----------|---------|---------|---------|
| | GUI | | | | | | |
| | 1(OPE) | -121 | -14709 | 0 | 0 | 0 | 0 |
| | 2(SUS) | -2 | -14709 | 0 | 0 | 0 | 0 |
| | 3(EXP) | -119 | 0 | 0 | 0 | 0 | 0 |
| | MAX | -121/L1 | - | 14709/L2 | | | |

7.4.4 Occasional Load cases:

Those present during rare intervals of operations. It includes the following loads:

7.4.4.1 Seismic Loads:

Seismic loading is one of the basic concepts of earthquake engineering which means application of an earthquake-generated agitation to a structure. As per preliminary information the values for the seismic acceleration (acceleration in ‘g’) to be considered are:

- North-South Direction
- East-West Direction
- Vertical Direction

Various seismic load cases to be considered are:

1. W+P1+T1=U1
2. W+P1+T1+U2
3. W+P1+T1+U3
4. W+P1+T1-U1
5. W+P1+T1-U2
6. W+P1+T1-U3
7. U1

8. U2

9. U3

10. -U1

11. -U2

12. -U3

7.4.4.2 Wind Loads:

Wind loading should be considered on a case by case basis. In determining the need for analysis, it should be noted that

- 10 NB lines and smaller lines, which are guided in accordance with good Practice; generally do not need specific analysis.
- The impact of wind shall be considered for long, exposed piping. The pipe work Involved are normally riser lines, flare-stack lines, turbine-exhaust stack and Piping on bridge. For properly supported and restraint lines, wind loading need Not be considered.
- When wind load is to be considered, a shape factor 0.65 and wind speed is to be Applied in two separate direction only (+/- X and +/- Z direction)
- Wind loading/ speed at 10m above mean sea level to be considered is 67.9 m/s (3 Sec gust), which is based on 100 years. Return (1hour average) wind speed of 44.83 m/s

Various Wind load cases considered are:

1. W+P1+T1+WIN1

2. W+P1+T1+WIN2

3. W+P1+T1+WIN3

4. W+P1+T1+WIN3

5. WIN1

6. WIN2

7. WIN3

8. WIN4

| Velocity(m/s) | Elevation(m) |
|---------------|--------------|
| 58 | 10 |
| 62 | 20 |
| 64 | 30 |
| 67.7 | 40 |
| 69.57 | 50 |
| 70.79 | 60 |
| 71.95 | 70 |
| 72.9 | 80 |
| 73.7 | 90 |
| 74.45 | 100 |

7.4.4.3 Wave Loads:

Wave loads are not considered for this project as it is an off shore plant and is designed keeping in mind the highest tide. Wave loads are primarily considered for designing on-shore Plants at areas close to the sea which has a history of flooding.

Chapter 8

CONCLUSION

We have successfully completed the project which involved development of piping layout for loading and unloading system in an onshore plant and analysis of the same using Caesar II.

The various task performed by us during this period are listed below and the observation and results obtained are furnished in this project report

- Process flow diagram (PFD) was developed.
- Piping and instrumentation diagram (P&IDs) were developed.
- Equipment's are designed in SP3D based on PFDs and P&IDs.
- 3D designing of piping layout was done for all the lines in complains with safety requirements mentioned in ASME B 31.3
- Generation of pipe isometrics for all lines.
- Selection of critical lines and non-critical lines
- Critical lines are subjected stress analysis under different load cases using Caesar II and it was found to have passed the test.
- Expansion loop calculation done.

REFERENCES

- [1] S. Crocker, “*Piping Handbook*”, United States of America: McGraw-Hill, 2000.
- [2] Sam kannappan, “*Pipe Stress Analysis*”, John wiley & Sons Publications, 1986 *Piping, ASME, New York*
- [3] W. C. Lyons, Working Guide to Petroleum and Natural Gas Production Engineering, Gulf Publishing, 2010.
- [4] *The American Society of Mechanical Engineers (2012), ASME B31.3 – 2000 Edition, Process Piping, ASME, New York.*
- [5] D. D. Vakharia and M. F. A, "Determination of maximum span between pipe," International Journal of Recent Trends in Engineering, 2009.
- [6] T. Prachi, D. Dhande and J. N. I, "Determination of Maximum Support Span, Location and Necessity of Pipe Support Using CAESAR II," International Journal of Innovative Research in Science, 2014.
- [7] T.V.V.Satyanarayana, V. sreenivasulu and D. kiran, "Modelling and Stress Analysis of Flare Piping," International Journal of Latest Trends in Engineering and Technology , 2013.
- [8] Shweta Bisht* and Farheen Jahan, "An Overview on Pipe Design using caesar II"International Journal on Emerging Technologies.